



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

126 S. Hamilton Street
P.O. Box 2985
Madison, Wisconsin 53701-2985
Phone: (608) 266-4635
Fax (608) 267-8739
www.cityofmadison.com

December 6, 2017

James Moravec
Potter Lawson Inc.
749 University Row Suite 300
Madison, WI 53705

RE: Legistar #48452 & #49222; Accela 'LNDUSE-2017-00104' -- Approval to amend a Planned Development - General Development Plan (PD-GDP), as well as approval of an Amended Planned Development - Specific Implementation Plan (PD-SIP) to construct an emergency generator facility for a hospital campus at **36 S. Brooks Street**.

Dear Mr. Moravec:

At their December 5, 2017 meeting, the Common Council **approved** your zoning map amendment requests to approve an Amended General Development Plan (PD-GDP) and to approve a Specific Implementation Plan (PD-SIP) at 36 S. Brooks Street. This approval allows for the construction of an emergency generator facility for the Meriter hospital campus. This approval is subject to the below conditions of approval that shall be satisfied prior to final approval and sign-off of the plans, recording of the Planned Development, and the issuance of permits.

Please contact Tim Troester of the City Engineering Division at (608) 267-1995 if you have questions related to these eleven (11) items:

1. All outstanding Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO16.23(9)(d)(4))
2. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)
3. The Applicant shall submit, prior to plan sign-off but after all revisions have been completed, a digital CAD file (single file) to the Engineering Division with any private storm and sanitary sewer utilities. The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number:

- a) Building Footprints
- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
- e) Right-of-Way lines (public and private)
- f) Lot lines or parcel lines if unplatted
- g) Lot numbers or the words unplatted
- h) Lot/Plat dimensions
- i) Street names
- j) Private on-site sanitary sewer utilities (including all connections to public sanitary)
- k) Private on-site storm sewer utilities (including all connections to public storm)

All other levels (contours, elevations, etc) are not to be included with this file submittal.

NOTE: Email CAD file transmissions are preferred to: bstanley@cityofmadison.com (East) or troester@cityofmadison.com (West). Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement, private on-site sanitary sewer utilities, or private on-site storm sewer utilities during construction will require a new CAD file.

4. The applicant shall submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or troester@cityofmadison.com (West). The digital copies shall be to scale, and shall have a scale bar on the plan set. (POLICY and MGO 37.09(2))
PDF submittals shall contain the following information:
 - a) Building Footprints
 - b) Internal Walkway Areas
 - c) Internal Site Parking Areas
 - d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
 - e) Right-of-Way lines (public and private)
 - f) Lot lines or parcel lines if unplatted
 - g) Lot numbers or the words unplatted
 - h) Lot/Plat dimensions
 - i) Street names
 - j) Stormwater Management Facilities
 - k) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans).
5. The Applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including:
 - a) SLAMM DAT files
 - b) RECARGA files
 - c) TR-55/HYDROCAD/Etc
 - d) Sediment loading calculations. If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided. (POLICY and MGO 37.09(2))

6. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year.
7. For Commercial sites < 1 acre in disturbance the City of Madison is an approved agent of the Department of Commerce and WDNR. As this project is on a site with disturbance area less than one (1) acres, and contains a commercial building, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of Commerce. No separate submittal to Commerce or the WDNR is required. (NOTIFICATION)
8. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to Reduce TSS by 80% off of the proposed development when compared with the existing site.
9. The Applicant shall replace all sidewalk and curb and gutter which abuts the property which is damaged by the construction or any sidewalk and curb and gutter which the City Engineer determines needs to be replaced because it is not at a desirable grade regardless of whether the condition existed prior to beginning construction. (POLICY)
10. All work in the public right-of-way shall be performed by a City licensed contractor. (MGO 16.23(9)(c)5) and MGO 23.01)
11. All damage to the pavement on Milton St, adjacent to this development shall be restored in accordance with the City of Madison's Pavement Patching Criteria. For additional information please see the following link: <http://www.cityofmadison.com/engineering/patchingCriteria.cfm> (POLICY)

Please contact Jeff Quamme, City Engineering Division - Mapping, at (608) 266-4097 if you have questions regarding the following three (3) items:

12. The address of the new generator plant is 1016 Milton St. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
13. This plant is replacing existing electrical generation plants on the Meriter site. Preliminary plans indicated the future installation of duct banks crossing Brooks Street. Applicant shall be aware any future private duct bank within a public right of way will require a privilege in streets agreement with the City of Madison.
14. Note: Real Estate Project 3762 for the skywalk attached to this parcel and lying above Brooks Street has been restarted and is to be completed and recorded to document the improvements.

Please contact Sean Malloy, Traffic Engineering Division, at (608) 266-5987 if you have questions regarding the following five (5) items:

15. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
16. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
17. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
18. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
19. The parking facility shall be modified to provide for adequate internal circulation for vehicles. This can be accommodated by eliminating a parking stall at the dead ends. The eliminated stall shall be modified to provide a turnaround area ten (10) to twelve (12) feet in width and signed with a "No Parking Anytime." Alternatively, if this lot is intended for employees only, the lot should be signed accordingly and noted on the plan.

Please contact Jenny Kirchgatter, Assistant Zoning Administrator, at (608) 266-4429 if you have questions regarding the following four (4) items:

20. Submit a complete site plan of the entire site showing the existing building and identifying existing site features such as the loading dock, walkways, entry features, overhead bridge and bicycle parking.
21. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect. Identify and label all proposed landscaping and existing landscaping to remain adjacent the existing building.
22. Exterior lighting provided shall be in accordance with City of Madison General Ordinances Section 10.085. Provide an exterior lighting plan and fixture cut sheets with the final plan submittal.
23. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning

Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.

Please contact Bill Sullivan, Fire Department, at (608) 261-9658 if you have questions regarding the following item:

24. The Madison Fire Department does not object to this proposal provided the project complies with all applicable fire codes and ordinances.

Please contact Janet Schmidt, Parks Department, at (608) 261-9688 if you have questions regarding the following three (3) items:

25. City Forestry will issue a removal permit for two Ash trees (14" diameter 2nd tree on Milton St as a preemptive Ash removal per Forestry & 11" diameter 3rd tree on Milton St as an Ash removal request). Please contact Brad Hofmann – bhofmann@cityofmadison.com or 266-4816 to obtain the street tree removal permit.
26. Two additional street trees are needed for this project. All street tree planting locations and trees species within the right of way shall be determined by City Forestry. Please submit a site plan (in PDF format) to Brad Hofmann – bhofmann@cityofmadison.com or 266-4816. Tree planting specifications can be found in section 209 of City of Madison Standard Specifications for Public Works Construction.
27. Existing street trees shall be protected. Please include the following note on the site plan: Contractor shall install tree protection fencing in the area between the curb and sidewalk and extend it at least 5 feet from both sides of the tree along the length of the terrace. No excavation is permitted within 5 feet of the outside edge of a tree trunk. If excavation within 5 feet of any tree is necessary, contractor shall contact City Forestry (266- 4816) prior to excavation to assess the impact to the tree and root system. Tree pruning shall be coordinated with City Forestry prior to the start of construction. Tree protection specifications can be found in section 107.13 of City of Madison Standard Specifications for Public Works Construction - <http://www.cityofmadison.com/business/pw/documents/StdSpecs/2013/Part1.pdf>. Any tree removals that are required for construction after the development plan is approved will require at least a 72 hour wait period before a tree removal permit can be issued by Forestry, to notify the Alder of the change in the tree plan.

Please contact Adam Wiederhoeft, Water Utility, at (608) 266-9121) if you have any questions regarding the following item:

28. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days' notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumberscontractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will

subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

The applicant is also required to satisfy the conditions of approval of the Urban Design Commission prior to the final staff approval of the project and the issuance of building permits. You may contact Janine Glaeser, the Urban Design Commission Secretary, at (608) 267-8740 if you have any questions about those conditions.

Please now follow the procedures listed below:

After the planned development has been revised per the above conditions, please submit ten (10) copies of a complete, fully dimensioned and scaled plan set to the Zoning Administrator for final review and comment. Also be sure to include any additional materials requested by these departments for their approval prior to sign off. The final site plan shall be accompanied by the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, 126 S. Hamilton Street. This submittal shall all also include one complete digital plan set in PDF format. The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their final approval.

Upon receipt of the aforementioned plans, documents and fees, and upon determining that they are complete, the Zoning Administrator shall record them with the Dane County Register of Deeds Office. The recorded originals will be returned to the applicant, with the recording information noted, when the Register of Deeds has completed the recording process.

If this plan is not recorded within one year of the date of approval by the Common Council, the approval shall be null and void. No construction or alteration of the property included in this application shall be permitted until a Specific Implementation Plan (SIP) has been approved and recorded. Within thirty-six (36) months of Common Council approval of the general development plan, the basic right of use for the areas, when in conformity with the approved specific implementation plan, shall lapse and be null and void unless 1) the project, as approved, is commenced by the issuance of a building permit, or 2) if an application for an extension is filed at least thirty (30) days prior to the expiration of the thirty-six (36) month period and the Plan Commission, after a public hearing pursuant to Sec. 28.181(5) determines that no changes in the surrounding area or neighborhood since approval of the general development plan render the project incompatible with current conditions and grants an extension of up to twenty-four (24) months in which to obtain a building permit. In no case shall an extension allow a building permit to be issued more than sixty (60) months after approval of the general development plan by the Common Council. If a new building permit is required pursuant to sec. 29.06(4), Madison General Ordinances, a new petition and approval process shall be required to obtain general development plan approval and specific implementation plan approval.

This property is not in a wellhead protection district. All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility. All operating private wells shall be identified and permitted by the Madison Water Utility and all unused private wells shall be abandoned in accordance with MGO Sec. 13.21.

If you have any questions regarding recording this plan or obtaining permits, please call Jenny Kirchgatter, Zoning Administrator, at (608) 266-4429. If I may be of any further assistance, please do not hesitate to contact me at (608) 243-0554.

Sincerely,



Sydney Prusak
Planner

cc: Tim Troester, Engineering Division
Jeff Quamme, Engineering Mapping
Eric Halvorson, Traffic Engineering Division
Bill Sullivan, Fire Department
Jenny Kirchgatter, Zoning Division
Janet Schmidt, Parks Division
Adam Wiederhoeft, Water Utility

For Official Use Only, Re: Final Plan Routing			
☒	Planning Div. (Prusak)	☒	Engineering Mapping Sec.
☒	Zoning Administrator	☒	Parks Division
☒	City Engineering	☒	Urban Design Commission
☒	Traffic Engineering	☐	Recycling Coord. (R&R)
☒	Fire Department	☒	Water Utility