



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017
215 Martin Luther King Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4635
www.cityofmadison.com

****BY E-MAIL ONLY****

June 23, 2021

Corey Bushcott
Raelyn Labs
3435 Richard Street
Madison, WI 53714

RE: Consideration of a conditional use in the Traditional Shopping Street (TSS) District for a building with less than 75% non-residential ground floor area to allow creation of a ground floor apartment at the rear of an existing commercial building at 1101 Williamson Street/403 S Ingersoll Street. (LNDUSE-2021-00040; ID 65475)

Dear Corey Bushcott;

On June 21, 2021, the Plan Commission found the standards met and **conditionally approved** your client's conditional use request at 1101 Williamson Street/403 S Ingersoll Street. In order to receive final approval of the conditional use, and for any permits to be issued for your project, the following conditions shall be satisfied:

Please contact Jeff Quamme of the City Engineering Division – Mapping Section at (608) 266-4097 if you have any questions regarding the following two (2) items:

1. Identify on the plans the Lot 1, Block 182 - 183 of the recorded Plat of Farwell's Replat of Blocks 165 - 240. Also the lot dimensions of the parcel are all incorrect and shall be corrected to match title.
2. Provide a full and complete legal description of the site or property being subjected to this application on the site plan.

Please contact Jenny Kirchgatter of the Zoning Division at (608) 266-4429 if you have any questions regarding the following four (4) items:

3. Bicycle parking for the exiting coffee shop and proposed dwelling unit shall comply with the requirements of Sections 28.141(4)(g) and 28.141(11). A minimum amount of bicycle parking equal to 5% of capacity of persons is required for the coffee shop. One (1) bicycle stall is required for the proposed dwelling unit. The bicycle stalls located in the public right-of-way do not count toward the minimum bicycle parking requirement. The owner may submit a request for a bicycle parking reduction with information to support the request per Section 28.141(5). Information such as the number and location of the bicycle stalls in the right-of-way can be used to support the argument for reducing the required number of spaces on the private property.

4. Screening is required adjacent the Zoning district boundary along the east side and rear property lines. Screening shall be provided along side and rear property boundaries between commercial/ mixed-use districts and residential districts. Screening shall consist of a solid wall, solid fence, or hedge with year-round foliage, between six (6) and eight (8) feet in height. For conditional uses, the Plan Commission may modify these requirements. Submit a detail or photo of the existing or proposed screening fence with the final plans.
5. Show the refuse disposal area on the site plan. All developments, except single family and two family developments, shall provide a refuse disposal area. If the refuse disposal area is located outside the building, it shall be screened on four (4) sides (including a gate for access) by a solid, commercial-grade wood fence, wall, or equivalent material with a minimum height of six (6) feet and not greater than eight (8) feet. Submit a detail of the trash enclosure if provided outside the building. Note that City issued trash containers are not required to be screened.
6. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.

Please contact Bill Sullivan of the Madison Fire Department at (608) 261-9658 if you have any questions regarding the following two (2) items:

7. Madison Fire Department recommends the installation of a residential fire sprinkler system. Additional information is available at the Home Fire Sprinkler Coalition website: <https://homefiresprinkler.org/buildingresidential-fire-sprinklers>
8. As required by MGO 10.34 and IFC 505.1, all residential and commercial buildings must have the approved address posted. The address numbers shall be 4 inches in height, numbers shall be in contrast to the background and visible from the street.

Please contact Kathleen Kane of the Parks Division at (608) 261-9671 if you have questions regarding the following item:

9. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new residential development associated with this project. This development is within the East Park-Infrastructure Impact Fee district. Please reference ID# 21012 when contacting Parks about this project.

Please contact Brad Hofmann of the Forestry Division at (608) 267-4908 if you have questions regarding the following seven (7) items:

10. Contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at 266-4816. Penalties and remediation shall be required. Add as a note on the plan set.

11. As defined by the Section 107.13 of City of Madison Standard Specifications for Public Works Construction: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches in diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry (266-4816) prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing. Tree protection specifications can be found on the following website: <https://www.cityofmadison.com/business/pw/specs.cfm> Add as a note on the plan set.
12. On this project, street tree protection zone fencing is required if any construction or storage of materials will be within the terrace area. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and, extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on the plan set.
13. Street tree pruning shall be coordinated with Madison Forestry at a minimum of two weeks prior to the start of construction for this project. All pruning shall follow the American National Standards Institute (ANSI) A300 - Part 1 Standards for pruning. Add as a note on the plan set.
14. Section 107.13(g) of City of Madison Standard Specifications for Public Works Construction addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on the plan set.
15. All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alderperson within who's district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the plan set.
16. An existing inventory of street trees located within the right of way shall be included on the landscape, site, demo, and utility plans. The inventory shall include the following: location, size (diameter at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is to be preserved or proposed to be removed and the reason for removal.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining permits for your project:

1. The applicant shall resubmit a PDF copy of the plan set and any other supporting materials that are necessary, as specified in this letter to Zoning@cityofmadison.com. (Note: A 20MB email limit applies and multiple transmittals may be required.). A check for the site plan review fee shall be mailed to the City of Madison Building Inspection Division; PO Box 2984; Madison, WI 53701-2984.
2. City Agencies who submitted conditions of approval will review your revised plans to verify that their conditions, along with any applicable requirements, have been satisfied. When the revised plans are submitted, the applicant will be emailed a hyperlink to a website to follow, in real time, which agencies have reviewed the revised documents, and signed off or need additional information.

3. This letter shall be signed by the applicant and property owner (if not the applicant) to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting building permit approval. [Signature block located below]

4. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. No alteration of a conditional use shall be permitted unless approved by the Plan Commission provided, however, the Zoning Administrator following consideration by the alderperson of the district, may approve minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the Plan Commission and the conditional use standards. This approval shall become null and void one (1) year after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within 6 months of the issuance of said building permit. Where the plans have not been altered from the Plan Commission’s approval, and the conditional use has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use permit.

If you have any questions regarding obtaining your building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at 261-9135.

Sincerely,



Chris Wells
 Planner

I hereby acknowledge that I understand and will comply with the above conditions of approval for this project.

Signature of Applicant

*Signature of Property Owner
 (If Not Applicant)*

cc: Jeff Quamme, City Engineering Division – Mapping Section
 Jenny Kirchgatter, Zoning Administrator
 Bill Sullivan, Fire Department
 Kate Kane, Parks Division
 Brad Hofmann, Parks Division–Forestry Section

LNDUSE-2021-00040			
For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Wells)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Other: Forestry
<input type="checkbox"/>	Water Utility	<input type="checkbox"/>	Other: