

Department of Planning & Community & Economic Development **Planning Division**

Website: www.cityofmadison.com

Madison Municipal Building 215 Martin Luther King, Jr. Boulevard P.O. Box 2985 Madison, Wisconsin 53701-2985 TDD 608 266-4747 FAX 608 266-8739 PH 608 266-4635

May 9, 2013

William Simpson FCM Corporation 133 S. Butler St. Madison, WI 53703

RE: Approval of the demolition of a commercial building for construction of a new two-story office building at 2635 University Avenue.

Dear Mr. Simpson:

At its May 6, 2013 meeting, the Plan Commission found the standards met and **approved** your client's demolition request for 2635 University Avenue, subject to the conditions below. In order to receive final approval of the demolition, and for any necessary permits to be issued for your project, the following conditions shall be met:

Please contact my office at 266-5974 with questions about the following item:

1. Final plans submitted for staff review and signoff shall include sufficient information to determine that rooftop screening standards are met.

Please contact Janet Dailey of the City Engineering Division at 261-9688 with questions regarding the following 19 items:

- 2. The existing building on this site proposed to be razed crosses underlying platted lot lines. The proposed new building will cross the same underlying platted lot line. Current State building code and City enforcement requires the underlying platted lot line be dissolved by Certified Survey Map (CSM) prior to issuance of a building permit. A CSM will also better memorialize the existing property boundary and title which is a direct benefit to the property owner. Have a CSM prepared for submittal to City Planning. The CSM shall be approved by the City and recorded with the Dane County Register of Deeds prior to issuance of a building permit.
- 3. The address of the new proposed building is 519 Farley Ave. After the demolition, the 2635 University Ave address will be inactivated and no longer valid.
 - NOTE: Please coordinate with Lori Zenchenko, 266-5952 regarding this condition, as a change to a new University Avenue address is being discussed by Engineering and Fire Department staff.
- 4. The proposed private storm sewer connection to the public storm seer shall require a structure on the existing public main.
- 5. The Applicant and / or their Contractor shall contact Ray Schneider of the Madison Metropolitan Sewerage District at 347-3628 for inspection of the sanitary sewer lateral prior to the plugging of the lateral and demolition of the building.

- 6. The Applicant shall close all abandoned driveways by replacing the curb in front of the driveways and restoring the terrace with grass (POLICY).
- 7. The Applicant shall replace all sidewalk and curb and gutter which abuts the property which is damaged by the construction or any sidewalk and curb and gutter which the City Engineer determines needs to be replaced because it is not at a desirable grade regardless of whether the condition existed prior to beginning construction (POLICY).
- 8. All work in the public right-of-way shall be performed by a City licensed contractor (MGO 16.23(9)(c)5) and MGO 23.01).
- 9. All damage to the pavement on <u>Farley Ave and University Ave</u>, adjacent to this development shall be restored in accordance with the City of Madison's Pavement Patching Criteria. For additional information please see the following link: http://www.cityofmadison.com/engineering/patchingCriteria.cfm (POLICY).
- 10. The plan set shall be revised to show a proposed private internal drainage system on the site. This information shall include the depths and locations of structures and the type of pipe to be used. POLICY AND MGO 10.29.
- 11. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
- 12. For Commercial sites < 1 acre in disturbance the City of Madison is an approved agent of the Department of Commerce and WDNR. As this project is on a site with disturbance area less than one (1) acres, and contains a commercial building, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of Commerce. No separate submittal to Commerce or the WDNR is required. (NOTIFICATION).
- 13. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to:
 - a) Reduce TSS off of the proposed development by 80% when compared with the existing site
 - b) Complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website as required by MGO Chapter 37.
- 14. The Applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Program Specialist in the Engineering Division (Lori Zenchenko). The digital CAD file shall be to scale and represent final construction. The single CAD file submittal can be either AutoCAD (dwg) Version 2001 or older, MicroStation (dgn) Version J or older, or Universal (dxf) format and contain only the following data, each on a separate layer name/level number:
 - a) Building Footprints
 - b) Internal Walkway Areas
 - c) Internal Site Parking Areas
 - d) Other Misc Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
 - e) Right-of-Way lines (public and private)
 - f) All Underlying Lot lines or parcel lines if unplatted
 - g) Lot numbers or the words "unplatted"
 - h) Lot/Plat dimensions
 - i) Street names

All other levels (contours, elevations, etc) are not to be included with this file submittal. NOTE: Email file transmissions preferred lzenchenko@cityofmadison.com. Include the site address in the subject line of this transmittal. Any changes or additions to the location of the

2635 University Ave. M ay 9, 2013 Page 3

building, sidewalks, parking/pavement during construction will require a new CAD file (POLICY and MGO 37.09(2) & 37.05(4)).

15. The applicant shall submit, prior to plan sign-off, digital PDF files to the Engineering Division (Jeff Benedict or Tim Troester). The digital copies shall be to scale, and shall have a scale bar on the plan set (POLICY and MGO 37.09(2).

PDF submittals shall contain the following information:

- a) Building footprints
- b) Internal walkway areas
- c) Internal site parking areas
- d) Lot lines and right-of-way lines
- e) Street names
- f) Stormwater Management Facilities
- g) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans)
- 16. The Applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including:
 - a) SLAMM DAT files
 - b) RECARGA files
 - c) TR-55/HYDROCAD/Etc
 - d) Sediment loading calculations
- 17. If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided (POLICY and MGO 37.09(2)).
- 18. The applicant shall obtain all necessary sewer connection permits and sewer plugging permits prior to any utility work (MGO 10.05(6)) and MGO 35.02(4)(c)(2)). This permit application is available on line at http://www.cityofmadison.com/engineering/permits.cfm.
- 19. Prior to approval, the owner or owner's representative shall obtain a permit to plug each existing sanitary sewer lateral that serves a building which is proposed for demolition. For each lateral to be plugged the owner shall complete a sewer lateral plugging application and pay the applicable permit fees. NOTE: As of January 1, 2013 new plugging procedures and permit fees go into effect. The new procedures and revised fee schedule is available on line at http://www.cityofmadison.com/engineering/permits.cfm (MGO CH 35.02(14)).
- 20. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service (POLICY).

Please contact Eric Halvorson, Traffic Engineering at 266-6572 with questions regarding the following 5 items:

- 21. The University Avenue Corridor study is currently under way. Traffic Engineering recommends building be set back from Right of Way along University and Farley to preserve future pedestrian, bicycle, transit and motor vehicle transportation needs at the intersection.
- 22. Plans submitted for approval shall include a pedestrian warning sign in addition to a stop sign at driveway exit to Farley to address neighborhood pedestrian concerns.
- 23. When the applicant shall submit plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing and proposed property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), adjacent driveway approaches to lots on either side and across the

- street, signage, percent of slope, semitrailer movements and vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'. Contact City Traffic Engineering if you have questions.
- 24. The Developer shall post a deposit and reimburse the City for all costs associated with any modifications to Traffic Signals, Street Lighting, Signing and Pavement Marking, and conduit and handholes, including labor, engineering and materials for both temporary and permanent installations.
- 25. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact Pat Anderson of the Zoning Office at 266-5978 with questions regarding the following 9 items:

- 26. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with MGO Chapter 31 Sign Codes prior to sign installations.
- 27. Sec. 28.185 (7)(a)5. requires that if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Mr. George Dreckmann. (608-267-2626).
- 28. Sec. 28.185 (10) Every person who is required to submit a reuse and recycling plan pursuant to Sec. 28.185(7)(a)5 shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition.
- 29. Subject to MGO Sec. 28.173(9)(b). Access and Entry. Buildings shall have a clearly defined, highly-visible customer entrance or entrances, marked by canopies, porticos, overhangs, arcades, facade recesses or projections, or similar features.
- 30. Combine the lots to legally make one lot via a Certified Survey Map. A property line cannot go through a building without a fire wall down the lot line pursuant to Section 705.1.1 of the International Building Code. CSM shall be approved before sign off of final plans.
- 31. Provide details of dumpster enclosure.
- 32. Bike parking shall comply with MGO Table 28I-3 (General Regulations). Provide three bike parking stalls in a safe and convenient location on an impervious surface to be shown on the final plan. NOTE: A bike-parking stall is two feet by six feet with a five-foot access area. Structures that require a user-supplied locking device shall be designed to accommodate U-shaped locking devices. Provide details of bike rack on final plan sets.
- 33. Section 28.076 (5) Alterations to Approved Designs. For buildings approved pursuant to (b) or (c) above, the Director of the Department of Planning, Community and Economic Development may approve minor alterations or additions if he/she determines that such alterations or additions are consistent with Sec. 28.071(3), if applicable, the Downtown Urban Design Guidelines, and the previously approved design.
- 34. Pursuant to Sec. 28.142 (3) Landscape Plan and Design Standards: Landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.

Please contact Bill Sullivan of the Madison Fire Department at 261-9658 if you have any questions regarding the following two items:

2635 University Ave. M ay 9, 2013 Page 5

- 35. Group B ambulatory health care facilities are required to have an automatic fire sprinkler system per IBC 903.2.2.
- 36. Please consider allowing Madison Fire Dept. to conduct training sequences prior to demolition. Contact MFD Training Division to discuss possibilities (608) 246-4587.

Please contact Kay Rutledge of the Madison Parks Division at 266-4714 if you have any questions about the following item:

37. Additional street trees are needed for this project. All street tree planting locations and trees species with the right of way shall be reviewed by City Forestry. Please submit a tree planting plan (in PDF format) to Dean Kahl – dkahl@cityofmadison.com or 266-4816. Approval and permitting of tree planting shall be obtained from the City Forester and/or the Board of Public Works prior to the approval of the site plan. Tree planting specifications can be found in section 209 of City of Madison Standard Specifications for Public Works Construction.

http://www.cityofmadison.com/business/pw/documents/StdSpecs/2013/Part2.pdf

Please reference ID # 13118 when contacting Parks about this project

Please contact Dennis Cawley of the Water Utility at 261-9243 if you have any questions about the following 3 items:

- 38. The Madison Water Utility shall be notified to remove the water meter prior to demolition.
- 39. This property is in wellhead protection district WP-6. The applicant shall determine if any hazardous chemicals, as defined by the Environmental Protection Agency, are stored or used on this site. If such chemicals are identified the applicant shall provide a report on the magnitude and/or frequency of these chemicals, as well as a plan for the storage or containment of these chemicals.
- 40. All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility. The Water Utility will not need to sign off the final plans, and will not need a copy of the approved plans.

2635 University Ave. M ay 9, 2013 Page 6

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

<u>No</u> interior, exterior or structural demolition or wrecking activities or remodeling activities (including material reclamation activities by the applicant or a third party) shall commence nor any wrecking or building permits be issued until the applicant has met all of the conditions of approval stated in this letter.

Please now follow the procedures listed below for obtaining your demolition permit:

- Please revise the plans per the above conditions and file nine (9) sets of complete, fully dimensioned, and to-scale plans, along with the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code. Also provide any other documentation requested herein with the Zoning Administrator, Room LL-100, Madison Municipal Building, 215 Martin Luther King, Jr. Boulevard.
- 2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting building permit approval.
- 3. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. This approval shall become null and void one year after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and demolition commenced within six months of the issuance of said building permit.

If you have any questions regarding obtaining the demolition approval, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 266-5974.

Sincerely,

Heather Stouder, AICP Planner

cc: Janet Dailey, City Engineering Division Eric Pederson, City Engineering Division Pat Anderson, Asst. Zoning Administrator Eric Halvorson, Traffic Engineering Bill Sullivan, Madison Fire Department Dennis Cawley, Water Utility Kay Rutledge, Parks Division I hereby acknowledge that I understand and will comply with the above conditions of approval for this conditional use permit.

Signature of Applicant

For Official Use Only, Re: Final Plan Routing			
\boxtimes	Planning Div. (H. Stouder)	\boxtimes	Engineering Mapping Sec.
\boxtimes	Zoning Administrator	\boxtimes	Parks Division
\boxtimes	City Engineering		Urban Design Commission
\boxtimes	Traffic Engineering		Recycling Coor. (R&R)
\boxtimes	Fire Department		Other: