



Legislation Details (With Text)

**File #:** 48827      **Version:** 1      **Name:** 56 Corry St  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 9/13/2017      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 9/19/2017  
**Enactment date:**      **Enactment #:**

**Title:** 56 Corry St (C-09-73-2017)  
 Architecture CSG/ Fink Horesch appealing 2009 IBC Table G01. The table requires a fire rating for a wall along a railroad right of way. The variance requested is to allow a non-rated wall along the railroad corridor. The Madison Fire Department recommends approval.  
 Alder District # 6

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 56 Corry St Variance Application 9-7-2017.pdf

Date	Ver.	Action By	Action	Result
9/19/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

**Title**  
 56 Corry St (C-09-73-2017)  
 Architecture CSG/ Fink Horesch appealing 2009 IBC Table G01. The table requires a fire rating for a wall along a railroad right of way. The variance requested is to allow a non-rated wall along the railroad corridor. The Madison Fire Department recommends approval.  
 Alder District # 6