



Legislation Details (With Text)

File #: 48827 **Version:** 1 **Name:** 56 Corry St
Type: Miscellaneous **Status:** Approved
File created: 9/13/2017 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 9/19/2017
Enactment date: **Enactment #:**
Title: 56 Corry St (C-09-73-2017)
Architecture CSG/ Fink Horesch appealing 2009 IBC Table G01. The table requires a fire rating for a wall along a railroad right of way. The variance requested is to allow a non-rated wall along the railroad corridor. The Madison Fire Department recommends approval.
Alder District # 6
Sponsors:
Indexes:
Code sections:
Attachments: 1. 56 Corry St Variance Application 9-7-2017.pdf

Date	Ver.	Action By	Action	Result
9/19/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

56 Corry St (C-09-73-2017)
Architecture CSG/ Fink Horesch appealing 2009 IBC Table G01. The table requires a fire rating for a wall along a railroad right of way. The variance requested is to allow a non-rated wall along the railroad corridor. The Madison Fire Department recommends approval.
Alder District # 6