



## Legislation Details (With Text)

---

<b>File #:</b>	61378	<b>Version:</b>	1	<b>Name:</b>	9604 Wilrich St
<b>Type:</b>	Miscellaneous	<b>Status:</b>		<b>Status:</b>	Approved
<b>File created:</b>	7/14/2020	<b>In control:</b>		<b>In control:</b>	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
<b>On agenda:</b>		<b>Final action:</b>		<b>Final action:</b>	7/21/2020
<b>Enactment date:</b>		<b>Enactment #:</b>			

**Title:** 9604 Wilrich St  
BLDVAR-2020-09024  
The applicant is seeking a variance from 2015 IBC 1006.2.1 requiring two exits or exit access doorways from any space in a R-2 occupancy with an occupant load exceeding the allowable limit of 10 individuals. The applicant is seeking permission to increase the allowable occupant load to 15 individuals for a single exit pathway. Alder District #9.

### Sponsors:

### Indexes:

### Code sections:

**Attachments:** 1. 9604 wilrich variance.pdf, 2. Wilrich St 9604 IBC 1006 MFD Position 7-13-2020.pdf, 3. 7-21-2020\_PublicComment-RegistrantsReport.pdf

Date	Ver.	Action By	Action	Result
7/21/2020	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

### Title

9604 Wilrich St  
BLDVAR-2020-09024

The applicant is seeking a variance from 2015 IBC 1006.2.1 requiring two exits or exit access doorways from any space in a R-2 occupancy with an occupant load exceeding the allowable limit of 10 individuals. The applicant is seeking permission to increase the allowable occupant load to 15 individuals for a single exit pathway. Alder District #9.