



Legislation Details (With Text)

File #: 70255 **Version:** 1 **Name:**
Type: Miscellaneous **Status:** Approved
File created: 2/24/2022 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 3/24/2022
Enactment date: **Enactment #:**
Title: 2 E Gilman
BLDVAR-2022-02587
The applicant is seeking a variance from the 2015 IBC 1024.5 requiring openings in exit passageways be limited to those necessary for exit access to the exit passageway from normally occupied spaces. Alder District 2.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 2 E Gilman app.pdf, 2. 2 E Gilman plan.pdf, 3. Gilman St 2 E IBC 402 MFD Position 2-21-2022.pdf

Date	Ver.	Action By	Action	Result
3/24/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

2 E Gilman
BLDVAR-2022-02587
The applicant is seeking a variance from the 2015 IBC 1024.5 requiring openings in exit passageways be limited to those necessary for exit access to the exit passageway from normally occupied spaces. Alder District 2.