



Legislation Details

File #: 70553 **Version:** 1 **Name:**
Type: Miscellaneous **Status:** Approved
File created: 3/16/2022 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 3/24/2022
Enactment date: **Enactment #:**
Title: 917 E Mifflin
BLDVAR-2022-03659
The applicant is seeking a variance from MGO 34.01(13)(a), adoption of the IFC. IFC section 3103.8.2 Temporary tents or membrane structures shall not be located within 20 feet of lot lines and buildings. The proposed tent is 7 feet away from the adjacent Press Box.
Alder District 6.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 917 E Mifflin app.pdf, 2. 917 E Mifflin MFD statement.pdf, 3. 917 E Mifflin plan.pdf

Date	Ver.	Action By	Action	Result
3/24/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	