



Legislation Details

---

**File #:** 30570      **Version:** 1      **Name:** 1315 Rutledge Street  
**Type:** Miscellaneous      **Status:** Held in Committee  
**File created:** 6/11/2013      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 3/31/2022  
**Enactment date:**      **Enactment #:**  
**Title:** 1315 Rutledge Street (M-06-49-2013)  
Grant Sovern and Lara Sutherland appealing SPS 321.03. The rule requires that remodeled areas over 400 square feet on the third floor have two exits or be sprinklered. The Variance requested is to allow 696 square feet with a provision for an egress window in the northeast facing side.  
**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. 1315 Rutledge St.pdf

Date	Ver.	Action By	Action	Result
7/16/2013	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD		
6/18/2013	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Table	Pass