



Legislation Details

File #: 41132 **Version:** 1 **Name:** 101 King St
Type: Miscellaneous **Status:** Approved
File created: 12/9/2015 **In control:** BOARD OF REVIEW
On agenda: **Final action:** 12/15/2015
Enactment date: **Enactment #:**
Title: 101 King St (C-12-59-2015)

Wesley Reynolds of OPN Architects appealing IBC 1104.4. The rule requires that when new space is created it needs to be accessible. In this case an elevator needs to be added for the 448 square feet of additional space. The request is to not provide the elevator.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 101 King St.pdf

Date	Ver.	Action By	Action	Result
12/15/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve with Amendment(s)	Pass