



Legislation Details

**File #:** 82005      **Version:** 1      **Name:** 750 Regent St  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 4/11/2024      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 4/16/2024  
**Enactment date:**      **Enactment #:**  
**Title:** 750 Regent St  
 BLDVAR-2024-05403  
 The applicant is seeking a variance from 2015 IBC 1019.3(4) requiring the vertical opening between stories to be protected by a draft curtain 18" in depth. Alder District #4  
**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. 750 Regent St plans.pdf, 2. BLDVAR-2024-05403 Application.pdf, 3. Regent Street 750 IBC 1019.3 MFD Position Statement 4-15-2024.pdf

Date	Ver.	Action By	Action	Result
4/16/2024	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	