



## Legislation Details

<b>File #:</b>	82005	<b>Version:</b>	1	<b>Name:</b>	750 Regent St
<b>Type:</b>	Miscellaneous	<b>Status:</b>		<b>Status:</b>	Approved
<b>File created:</b>	4/11/2024	<b>In control:</b>		<b>In control:</b>	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
<b>On agenda:</b>		<b>Final action:</b>		<b>Final action:</b>	4/16/2024
<b>Enactment date:</b>		<b>Enactment #:</b>			
<b>Title:</b>	750 Regent St BLDVAR-2024-05403 The applicant is seeking a variance from 2015 IBC 1019.3(4) requiring the vertical opening between stories to be protected by a draft curtain 18" in depth. Alder District #4				
<b>Sponsors:</b>					
<b>Indexes:</b>					
<b>Code sections:</b>					
<b>Attachments:</b>	1. 750 Regent St plans.pdf, 2. BLDVAR-2024-05403 Application.pdf, 3. Regent Street 750 IBC 1019.3 MFD Position Statement 4-15-2024.pdf				

Date	Ver.	Action By	Action	Result
4/16/2024	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	