



## Legislation Text

---

**File #:** 70553, **Version:** 1

---

### Title

917 E Mifflin

BLDVAR-2022-03659

The applicant is seeking a variance from MGO 34.01(13)(a), adoption of the IFC. IFC section 3103.8.2 Temporary tents or membrane structures shall not be located within 20 feet of lot lines and buildings. The proposed tent is 7 feet away from the adjacent Press Box.  
Alder District 6.