



Legislation Details

File #: 70844 **Version:** 1 **Name:**
Type: Miscellaneous **Status:** Approved
File created: 4/8/2022 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 4/19/2022
Enactment date: **Enactment #:**

Title: 6106 Riva Rd
BLDVAR-2022-04284
The applicant is seeking a variance to SPS 321.03(7)(b) requiring exit doors be openable from the interior without the use of a key. The prospective property owner is proposing the installation of a magnetic locking system within the home to provide support for a resident with special health and safety needs and prohibit the resident from leaving without supervision. Alder District 10.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 6106 RIVA RD application.pdf

Date	Ver.	Action By	Action	Result
4/19/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	