



Legislation Details

**File #:** 49146      **Version:** 1      **Name:** 2221 Mustang Way (C-10-75-2017)  
Chris Kilen of Kilen Engineering appealing IBC 503.1 and IBC 903.2.4. The rule requires automatic sprinklers because the addition exceeds the area limits. The variance is requested because a fire wall would restrict move

**Type:** Miscellaneous      **Status:** Approved

**File created:** 10/9/2017      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD

**On agenda:**      **Final action:** 10/17/2017

**Enactment date:**      **Enactment #:**

**Title:** 2221 Mustang Way (C-10-75-2017)  
Chris Kilen of Kilen Engineering appealing IBC 503.1 and IBC 903.2.4. The rule requires automatic sprinklers because the addition exceeds the area limits. The variance is requested because a fire wall would restrict movement. The proposal is to sprinkle entire building over the next ten years. The Madison Fire Department supports the variance as long as all high-piled and Group A plastics storage is sprinkled. The balance of the building shall be sprinkled by 12-31-2024.  
Alder District 16

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 2221 Mustang Way.pdf

Date	Ver.	Action By	Action	Result
10/17/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	