



Legislation Details

File #: 30895 **Version:** 1 **Name:** 2402 S. Park Street
Type: Miscellaneous **Status:** Approved
File created: 7/10/2013 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 7/16/2013
Enactment date: **Enactment #:**

Title: 2402 S. Park Street (C-07-51-2013)
Haag Muller, Inc. appealing IBC 903.2.1.2. The rule requires an automatic sprinkler system be provided for areas over 5,000 square feet. The Variance requested is to allow a 100 square foot addition that would bring the total area to 5,199 square feet, without adding sprinklers. Additional means of safety are being provided by enhanced egress lighting.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 2402 S Park St.pdf

Date	Ver.	Action By	Action	Result
7/16/2013	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass