



Legislation Details

File #: 41129 **Version:** 1 **Name:** 2747 Stevens St
Type: Miscellaneous **Status:** Filed
File created: 12/9/2015 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 12/15/2015
Enactment date: **Enactment #:**
Title: 2747 Stevens St (M-12-55-2015)

Advanced Remodel appealing MGO 29.22. The code adopt SPS 321.04 that requires new stairways have risers less than 8 inches. The variance requested is to allow the new stairway to have 10 inch risers.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 2747 Stevens St.pdf

Date	Ver.	Action By	Action	Result
12/15/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Deny	