



Legislation Details

File #: 49843 **Version:** 1 **Name:** 1929 Winnebago St
Type: Miscellaneous **Status:** Approved
File created: 12/13/2017 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 2/21/2018
Enactment date: **Enactment #:**

Title: 1929 Winnebago St (C-12-88-2017)
Jacob Morrison of AIA appealing IBC 2009 - 1208.2. The rule requires ceiling heights to be 7'0". The variance requested is to allow the ceiling height in the basement to be 6'10". The finished ceiling would be 6'7". The area would be storage and prep only.
Alder District 6

Sponsors:

Indexes:

Code sections:

Attachments: 1. Winnebago St 1929 C-12-88-2017.pdf, 2. Winnebago St 1929 C-12-88-2017 Revised.pdf

Date	Ver.	Action By	Action	Result
2/21/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	
12/19/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Table	