



Legislation Details

File #: 41128 **Version:** 1 **Name:** 316 W. Washington Avenue
Type: Miscellaneous **Status:** Approved
File created: 12/9/2015 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 12/15/2015
Enactment date: **Enactment #:**
Title: 316 W. Washington Avenue (C-12-58-2015)

Ray White of Dimension IV appeals IBC 1023.6 penetrations into an exit stairway. The code does not allow metal pipes, conduits, and ducts to pass between exit corridors that do not serve the corridor. The variance requested is to allow the existing pipes to remain. The Madison Fire Department supports the variance.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 316 W. Washington.pdf

Date	Ver.	Action By	Action	Result
12/15/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	