



Legislation Details (With Text)

| | | | | | |
|------------------------|--------------------------------|----------------------|---|----------------------|--|
| File #: | 41129 | Version: | 1 | Name: | 2747 Stevens St |
| Type: | Miscellaneous | Status: | | Status: | Filed |
| File created: | 12/9/2015 | In control: | | In control: | BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD |
| On agenda: | | Final action: | | Final action: | 12/15/2015 |
| Enactment date: | | Enactment #: | | | |
| Title: | 2747 Stevens St (M-12-55-2015) | | | | |

Advanced Remodel appealing MGO 29.22. The code adopt SPS 321.04 that requires new stairways have risers less than 8 inches. The variance requested is to allow the new stairway to have 10 inch risers.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 2747 Stevens St.pdf

| Date | Ver. | Action By | Action | Result |
|------------|------|---|--------|--------|
| 12/15/2015 | 1 | BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD | Deny | |

Title

2747 Stevens St (M-12-55-2015)

Advanced Remodel appealing MGO 29.22. The code adopt SPS 321.04 that requires new stairways have risers less than 8 inches. The variance requested is to allow the new stairway to have 10 inch risers.