



Legislation Details

File #:	41129	Version:	1	Name:	2747 Stevens St
Type:	Miscellaneous	Status:		Status:	Filed
File created:	12/9/2015	In control:		In control:	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda:		Final action:		Final action:	12/15/2015
Enactment date:		Enactment #:			
Title:	2747 Stevens St (M-12-55-2015)				

Advanced Remodel appealing MGO 29.22. The code adopt SPS 321.04 that requires new stairways have risers less than 8 inches. The variance requested is to allow the new stairway to have 10 inch risers.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 2747 Stevens St.pdf

Date	Ver.	Action By	Action	Result
12/15/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Deny	