



Legislation Details (With Text)

File #:	41131	Version:	1	Name:	23 & 25 N. Pinckney
Type:	Miscellaneous	Status:		Status:	Held in Committee
File created:	12/9/2015	In control:		In control:	BOARD OF REVIEW
On agenda:		Final action:		Final action:	3/31/2022
Enactment date:		Enactment #:			

Title: 23 & 25 N. Pinckney (C-12-57-2015)

McFadden & Company appeals IBC Table 705.8. The rule does not allow openings on a property line. The variance requested is to allow a new opening. The Madison Fire Department opposes the variance.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 23 25 N. Pinckney.pdf

Date	Ver.	Action By	Action	Result
12/15/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Table	

Title

23 & 25 N. Pinckney (C-12-57-2015)

McFadden & Company appeals IBC Table 705.8. The rule does not allow openings on a property line. The variance requested is to allow a new opening. The Madison Fire Department opposes the variance.