



## Legislation Details

---

**File #:** 45475      **Version:** 1      **Name:** 4310 MOHAWK DR  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 12/15/2016      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 12/20/2016  
**Enactment date:**      **Enactment #:**  
**Title:** 4310 Mohawk Dr (C-12-75-2016)  
Conor Nelan of Cold Spring Design appealing IBC 1208.2. The rule requires clearance at obstructions to be 7' 6". The variance requested is to allow a beam 7' 0" and one at 7' 3. The Madison Fire Department recommends conditional approval. 10th Ald. Dist.  
**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. 4310 MOHAWK DR.pdf

Date	Ver.	Action By	Action	Result
12/20/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	