



Legislation Details (With Text)

File #: 45476 **Version:** 1 **Name:** 560 NORTH ST
Type: Miscellaneous **Status:** Approved
File created: 12/15/2016 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 12/20/2016
Enactment date: **Enactment #:**
Title: 560 North St (C-12-76-2016)
William Tracy appealing IBC 1208.2. The rule requires clearance at obstructions to be 7' 6". The variance requested is to allow existing clearance of 6' 7". The Madison Fire Department differed to the board. 12th Ald. Dist.

Sponsors:
Indexes:
Code sections:
Attachments: 1. 560 NORTH ST.pdf

Date	Ver.	Action By	Action	Result
12/20/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title
560 North St (C-12-76-2016)
William Tracy appealing IBC 1208.2. The rule requires clearance at obstructions to be 7' 6". The variance requested is to allow existing clearance of 6' 7". The Madison Fire Department differed to the board. 12th Ald. Dist.