



## Legislation Details

---

<b>File #:</b>	47296	<b>Version:</b>	1	<b>Name:</b>	432 W GORHAM ST
<b>Type:</b>	Miscellaneous	<b>Status:</b>		<b>Status:</b>	Approved
<b>File created:</b>	5/11/2017	<b>In control:</b>		<b>In control:</b>	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
<b>On agenda:</b>		<b>Final action:</b>		<b>Final action:</b>	5/16/2017
<b>Enactment date:</b>		<b>Enactment #:</b>			

**Title:** 432 W Gorham St (C-05-29-2017)  
Antunovich Associates appealing IBC 3007.4.4. The rule requires that the Fire Service Access Elevator Lobby be a minimum of 150 sq. ft. in area with a minimum dimension of 8'. The variance requested is to allow a lobby of 184 sq. ft. with dimensions of 7'2" x 25'9". The Madison Fire Department recommends approval. Aldermanic District 4

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 432 W GORHAM ST.pdf

Date	Ver.	Action By	Action	Result
5/16/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	