



Legislation Details (With Text)

File #: 48382 **Version:** 1 **Name:** 4601 Frey St (C-08-72-2017)
Josh Wilcox of Gary Brink & Associates appealing IFC D105.2 Aerial Fire Apparatus Access Roads. The variance requested is to reduce the fire lane on Frey Street from 26' to 19'6" in width. The Madison Fire Department supports

Type: Miscellaneous **Status:** Approved

File created: 8/9/2017 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD

On agenda: **Final action:** 8/15/2017

Enactment date: **Enactment #:**

Title: 4601 Frey St (C-08-72-2017)
Josh Wilcox of Gary Brink & Associates appealing IFC D105.2 Aerial Fire Apparatus Access Roads. The variance requested is to reduce the fire lane on Frey Street from 26' to 19'6" in width. The Madison Fire Department supports the variance. Alder District #11.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 4601 Frey St.pdf

Date	Ver.	Action By	Action	Result
8/15/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

4601 Frey St (C-08-72-2017)
Josh Wilcox of Gary Brink & Associates appealing IFC D105.2 Aerial Fire Apparatus Access Roads. The variance requested is to reduce the fire lane on Frey Street from 26' to 19'6" in width. The Madison Fire Department supports the variance. Alder District #11.