



Legislation Details (With Text)

File #: 49168 **Version:** 1 **Name:** 1705-1721 Autumn Lake Pkwy (C-10-78-2017)
Type: Miscellaneous **Status:** Approved
File created: 10/10/2017 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 10/17/2017
Enactment date: **Enactment #:**
Title: 1705-1721 Autumn Lake Pkwy (C-10-78-2017)
Randy Bruce of Knothe & Bruce appealing IBC 706.1.1. The proposal is to build a commercial 9-unit building connected as one, on 9 parcels, each 24 feet wide. The proposal is to construct a one-hour fire barrier between the units. Alder District 17

Sponsors:

Indexes:

Code sections:

Attachments: 1. 1705 Autumn Pky Application.pdf, 2. 1705-1721 Autumn Lake Pky.PDF

Date	Ver.	Action By	Action	Result
10/17/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

1705-1721 Autumn Lake Pkwy (C-10-78-2017)
Randy Bruce of Knothe & Bruce appealing IBC 706.1.1. The proposal is to build a commercial 9-unit building connected as one, on 9 parcels, each 24 feet wide. The proposal is to construct a one-hour fire barrier between the units. Alder District 17