



## Legislation Details

**File #:** 49168 **Version:** 1 **Name:** 1705-1721 Autumn Lake Pkwy (C-10-78-2017)  
**Type:** Miscellaneous **Status:** Approved  
**File created:** 10/10/2017 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE  
CODE AND LICENSING APPEALS BOARD  
**On agenda:** **Final action:** 10/17/2017  
**Enactment date:** **Enactment #:**  
**Title:** 1705-1721 Autumn Lake Pkwy (C-10-78-2017)  
Randy Bruce of Knothe & Bruce appealing IBC 706.1.1. The proposal is to build a commercial 9-unit  
building connected as one, on 9 parcels, each 24 feet wide. The proposal is to construct a one-hour  
fire barrier between the units. Alder District 17

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 1705 Autumn Pky Application.pdf, 2. 1705-1721 Autumn Lake Pky.PDF

Date	Ver.	Action By	Action	Result
10/17/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	