



Legislation Text

File #: 41129, **Version:** 1

Title

2747 Stevens St (M-12-55-2015)

Advanced Remodel appealing MGO 29.22. The code adopt SPS 321.04 that requires new stairways have risers less than 8 inches. The variance requested is to allow the new stairway to have 10 inch risers.