



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Legislation Text

File #: 41131, **Version:** 1

Title

23 & 25 N. Pinckney (C-12-57-2015)

McFadden & Company appeals IBC Table 705.8. The rule does not allow openings on a property line. The variance requested is to allow a new opening. The Madison Fire Department opposes the variance.