

BPW Meeting November 10, 2010:
Review of Projects by Engineering Environmental Staff for Impacts to Water Resources

6. Syene Road Assessment District

This project will disturb over one acre of land, which will require a WRAPP from the Department of Natural Resources and an Erosion Control/Stormwater Management Permit from City Engineering. (Jim Wolfe, City Engineering)

7. Sycamore Avenue Assessment District

This project will disturb over one acre of land, which will require a WRAPP from the Department of Natural Resources and an Erosion Control/Stormwater Management Permit from City Engineering. (Eric Dundee, City Engineering)

8. Mendota Street Assessment District

This project will disturb over one acre of land, which will require a WRAPP from the Department of Natural Resources and an Erosion Control/Stormwater Management Permit from City Engineering. (Eric Dundee, City Engineering)

9. Thorp Street Assessment District

This project will disturb over 4,000 square feet, which will require an Erosion Control/Stormwater Management Permit from City Engineering, but will not require a permit from the DNR since disturbance is less than one acre. (Eric Dundee, City Engineering)

10. Ivy Street Assessment District

This project will disturb over 4,000 square feet, which will require an Erosion Control/Stormwater Management Permit from City Engineering, but will not require a permit from the DNR since disturbance is less than one acre. (Eric Dundee, City Engineering)

Prepared By: *Genesis Steinwart*

Date: *11/10/11*