



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017
215 Martin Luther King, Jr. Blvd
P.O. Box 2985
Madison, Wisconsin 53701-2985
Phone: (608) 266-4635
www.cityofmadison.com

November 9, 2021

Jim Triatik
Sullivan DesignBuild
1314 Emil St
Madison, WI 53713

RE: Legistar #67285; Accela 'LNDUSE-2021-00093' -- Approval of a demolition permit at 5802 Odana Road

Dear Jim:

At its November 8 meeting, the Plan Commission, meeting in regular session, found the standards met and approved your technical demolition permit at **5802 Odana Road**. In order to receive final approval of the demolition permit and for any other permits that may need to be issued for your project, the following conditions shall be met:

Please contact Jacob Moskowitz, Assistant Zoning Administrator at (608) 266-4560 if you have any questions regarding the following five (5) items:

1. Section 28.185(7)(a)6. requires that if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Bryan Johnson (608-266-4682).
2. Section 28.185(10) Every person who is required to submit a reuse and recycling plan pursuant to Sec. 28.185(7)(a)5. shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition.
3. Section 28.185(9)(a) A demolition or removal permit is valid for one (1) year from the date of the Plan Commission.
4. Provide elevations with glass detail consistent with Sec. 28.129 Bird-Safe Glass Requirements. Sec. 28.129 applies only to the added windows.
5. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.

Please contact Wayne Buckley of the Forestry Section at (608) 266-4892 if you have any questions regarding the following eight (8) items:

6. Damaging Contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at 266-4816. Penalties and remediation shall be required. Add as a note on the plan set.
7. Excavation As defined by the Section 107.13 of City of Madison Standard Specifications for Public Works Construction: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches in diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry (266-4816) prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing. Tree protection specifications can be found on the following website: <https://www.cityofmadison.com/business/pw/specs.cfm> Add as a note on the plan set.
8. Protection On this project, street tree protection zone fencing is required. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and, extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on the plan set.
9. Pruning Street tree pruning shall be coordinated with Madison Forestry at a minimum of two weeks prior to the start of construction for this project. All pruning shall follow the American National Standards Institute (ANSI) A300 - Part 1 Standards for pruning. Add as a note on the plan set.
10. Soil Section 107.13(g) of City of Madison Standard Specifications for Public Works Construction addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on the plan set.
11. Street All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alderperson within who's district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the plan set.
12. Tree An existing inventory of street trees located within the right of way shall be included on the landscape, site, demo, and utility plans. The inventory shall include the following: location, size (diameter at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is proposed to be removed and the reason for removal.

13. Tree City Forestry will issue a street tree removal permit for (X) tree(s) (dbh) diameter (variety) tree due to (reason) at (location). Add as a note on the plan set.

Please contact Tim Sobota of Metro Transit at (608) 261-4289 if you have any questions regarding the following three (3) item:

14. In coordination with any public works improvements, the applicant shall maintain or replace the concrete boarding terrace surface at the existing Metro bus stop on the north side of Odana Road, west of Tokay Boulevard (#6952).
15. The applicant shall include the location of these facilities on the final documents filed with their permit application, so that Metro Transit may review and effectively plan for City transit access to this property.
16. Metro Transit operates daily all-day transit service along Odana Road and Tokay Boulevard adjacent this property - with trips at least every 60 minutes.


*Items not directly related to the demolition permit are reference items for future permitted use site plan review. **Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.***

Please now follow the procedures listed below for obtaining your demolition permit:

1. After the plans have been revised per the above conditions, please **one (1) complete digital plan set in PDF format** of complete, fully dimensioned, and to-scale plans; the appropriate site plan review application and [site plan review fee pursuant to Section 28.206](#) of the Zoning Code; and any other documentation requested herein to the Zoning Administrator at zoning@cityofmadison.com. (Note that that an individual email cannot exceed 20MB and it is the responsibility of the applicant to present files in a manner that can be accepted. Please email zoning@cityofmadison.com regarding questions or if you need alternative filing options. The check for the **site plan review** fee shall be mailed to the City of Madison Building Inspection Division; PO Box 2984; Madison, WI 53701-2984.) The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
3. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0455.

Sincerely,



Colin Punt
Planner

cc: Jacob Moskowitz, Asst. Zoning Administrator
Wayne Buckley, Forestry Section
Tim Sobota, Metro Transit
Bryan Johnson, Streets Division

I hereby acknowledge that I understand and will comply with the above conditions of approval.

Signature of Applicant

Signature of Property Owner (if not the applicant)

LNDUSE-2021-00093			
For Official Use Only, Re: Final Plan Routing			
<input type="checkbox"/>	Planning Div. (Punt)	<input type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input type="checkbox"/>	Parks Division
<input type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input type="checkbox"/>	Traffic Engineering	<input checked="" type="checkbox"/>	Recycling Coord. (R&R)
<input type="checkbox"/>	Fire Department	<input type="checkbox"/>	Water Utility
<input checked="" type="checkbox"/>	Metro Transit	<input checked="" type="checkbox"/>	Other: Forestry