

GLENVIEW DR

GLENVIEW DR

WOODLAWN DR

EXISTING 10" RCP SANITARY MAIN
AT 0.15% SLOPE
(MINIMUM FOR NEW 10" IS 0.28%)
CURRENTLY FLOWS NORTH TO
GLENVIEW DR AND THEN SOUTH
THROUGH EASEMENT

PROPOSED 12" PVC SANITARY MAIN
AT 0.22% WOULD MEET MINIMUM
DESIGN SLOPES AND INCREASE CAPACITY

EXISTING 12" CIP LINED SANITARY MAIN
TO BE ABANDONED

SNOW-ESMT
(PLAT)
DOC 1553295

EDNA TAYLOR PARK





LEONA TAYLOR
BOSTON PUBLIC LIBRARY
1601

DOGS
NOT
ALLOWED
IN
THIS
AREA

03.21.2018 13:20



03.21.2018 13:18



03/21/2018 13:19