



**City of Madison**

**ELECTRICAL**

**Permit**

**Building Inspection Division**

126 South Hamilton St  
 P.O. Box 2984  
 Madison WI 53701-2984  
 Phone (608)266-4551  
 Fax (608)266-6377

Property located at: <b>201 S GAMMON RD</b>	Permit date: <b>08/13/2018</b>	Permit number: <b>BLDELE-2018-11184</b>
Owner name <b>MADISON METRO SCHOOL DIST</b>	Owner mailing address <b>545 W DAYTON ST MADISON, WI 53703</b>	

Contractor Name: <b>FORWARD ELECTRIC INC</b>	License holder number <b>252204</b>
Contractor Mailing address <b>6909 RAYWOOD RD MADISON, WI 53713</b>	Phone <b>(608) 221-1945</b>  <b>jennifer@forwardelectric.com</b>

This permit is issued for execution of the work indicated. It is hereby agreed that all work will be installed in accordance with all City of Madison Ordinances and department rules relating to such work.

TYPE OF BUILDING: **COMMERCIAL**  
 PROJECT DESC: **NEW LIGHTING FOR FOOTBALL AND BASEBALL FIELDS**  
 NATURE OF JOB: **REPAIR/ALTERATION**

**EXISTING BUILDING**

(Number of Openings Added) (Includes: Convenience Outlets, Switches, Fixture, Fixed Appliances, etc.)

- Minimum fee \$15.00
- \$2.00 per opening for the first 20 openings, plus
- \$1.50 per opening for the additional 21-40 openings, plus
- \$1.00 per opening for the additional 41-99 openings, plus
- \$0.50 per opening for all openings over 100.

**FEES:**

Item Description	Units	Fee
Number of Openings Added or Moved	15	30.00

TOTAL INSPECTION FEES: 30.00

**Inspector Assigned**

James Ruetten  
 608-266-4554  
 jruetten@cityofmadison.com

ElectricalPermit\_20180813\_133020.pdf - (Read-Only)

Home Annotations Edit View Collaboration

Check Out Check in Discard Check Out Check In/Out

Download Properties Edit Properties Copy

Manage Bookmarks

Attachment Link

Email

Related Documents Document Set Explorer Documents Document

Linked Documents Document

Search Find

Search



# City of Madison

## ELECTRICAL

### Permit

**Building Inspection Division**  
 126 South Hamilton St  
 P.O. Box 2984  
 Madison WI 53701-2984  
 Phone (608)266-4551  
 Fax (608)266-6377

Property located at: <b>201 S GAMMON RD</b>	Permit date: <b>08/13/2018</b>	Permit number: <b>BLDELE-2018-11184</b>
Owner name <b>MADISON METRO SCHOOL DIST</b>	Owner mailing address <b>545 W DAYTON ST MADISON, WI 53703</b>	

Contractor Name: <b>FORWARD ELECTRIC INC</b>	License holder number <b>252204</b>
Contractor Mailing address <b>6909 RAYWOOD RD</b>	Phone <b>(608) 221-1945</b>



# City of Madison Site Plan Verification

**PROJECT:** LNDSPP-2018-00101

**Address:** 201 S Gammon RD

**Current Revision #:** 0

**Submitted by:** Forward Electric

**Contact:** Jenn Luhman  
(608) 221-1945  
jennifer@forwardelectric.com

**Project Type:** Permitted Use Site Plan Review

**Description:** Updating lighting for Memorial High School's football and baseball fields

**Status:** Approved

**Revision History:** 0

Review	Status	Reviewer	Reviewed
Lighting Review	APPROVED	Steve Rewey	Aug 2 2018
Urban Design Commission Review	APPROVED	Janine Glaeser	Aug 6 2018
Zoning Review	APPROVED	Christina Thiele	Jul 31 2018

## URBAN DESIGN COMMISSION

**Note** **Comment Date:** 08/06/2018

Building Plan review team to confirm no light trespass and full light cut-off fixtures.

## ZONING

**Supplement Accepted** **Comment Date:** 07/30/2018

Submit \$50 site plan review fee. Checks are made out to City of Madison.

**Supplement Accepted** **Comment Date:** 07/30/2018

Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.

\*\*Applicant provided the date 9/1/18\*\*





# Madison Memorial High School

Madison, WI

## Lighting System

Pole / Fixture Summary						
Pole ID	Pole Height	Mtg Height	Fixture Qty	Luminaire Type	Load	Circuit
F1-F2	80'	15'	2	TLC-BT-575	1.15 kW	A
		80'	11	TLC-LED-1150	12.65 kW	A
F3-F4	80'	15'	2	TLC-BT-575	1.15 kW	A
		80'	12	TLC-LED-1150	13.80 kW	A
		50'	1	TLC-LED-400	0.40 kW	A
<b>4</b>			<b>56</b>		<b>58.30 kW</b>	


Circuit Summary			
Circuit	Description	Load	Fixture Qty
A	Football	58.3 kW	56

Fixture Type Summary							
Type	Source	Wattage	Lumens	L90	L80	L70	Quantity
TLC-LED-1150	LED 5700K - 75 CRI	1150W	121,000	>63,500	>63,500	>63,500	46
TLC-BT-575	LED 5700K - 75 CRI	575W	52,000	>63,500	>63,500	>63,500	8
TLC-LED-400	LED 5700K - 75 CRI	400W	38,600	>63,500	>63,500	>63,500	2

## Light Level Summary

Calculation Grid Summary								
Grid Name	Calculation Metric	Illumination					Circuits	Fixture Qty
		Ave	Min	Max	Max/Min	Ave/Min		
Bleachers	Horizontal	4.60	0	14	62.20		A	56
Football	Horizontal Illuminance	50.8	41	62	1.50	1.24	A	56
Soccer	Horizontal Illuminance	51	41	63	1.56	1.24	A	56
Track	Horizontal Illuminance	16.3	0	44	205.30		A	56

From Hometown to Professional




We Make It Happen.™

Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2018 Musco Sports Lighting, LLC.



**EQUIPMENT LIST FOR AREAS SHOWN**

QTY	Pole			Luminaires				
	LOCATION	SIZE	GRADE ELEVATION	MOUNTING HEIGHT	LUMINAIRE TYPE	QTY / POLE	THIS GRID	OTHER GRIDS
2	F1-F2	80'	-	15'	TLC-BT-575	2	2	0
				80'	TLC-LED-1150	11	11	0
2	F3-F4	80'	-	15'	TLC-BT-575	2	2	0
				50'	TLC-LED-400	1	1	0
				80'	TLC-LED-1150	12	12	0
4	TOTALS:					56	56	0



Pole location(s) ⊕ dimensions are relative to 0,0 reference point(s) ⊗

ENGINEERED DESIGN By: Connor Ramstead • File #163423-p-FB • 23-May-18

**Madison Memorial High School**

Madison, WI

**GRID SUMMARY**

Name: Football  
 Size: 360' x 160'  
 Spacing: 30.0' x 30.0'  
 Height: 3.0' above grade

**ILLUMINATION SUMMARY**

MAINTAINED HORIZONTAL FOOTCANDLES  
 Entire Grid

Guaranteed Average: 50  
 Scan Average: 50.77  
 Maximum: 62  
 Minimum: 41  
 Avg / Min: 1.23  
 Guaranteed Max / Min: 2  
 Max / Min: 1.50  
 UG (adjacent pts): 1.29  
 CU: 0.54  
 No. of Points: 72

**LUMINAIRE INFORMATION**

Color / CRI: 5700K - 75 CRI  
 Luminaire Output: 121,000 / 52,000 / 38,600 lumens  
 No. of Luminaires: 56  
 Total Load: 58.3 kW

Luminaire Type	L90 hrs	L80 hrs	L70 hrs
TLC-LED-1150	>63,500	>63,500	>63,500
TLC-BT-575	>63,500	>63,500	>63,500
TLC-LED-400	>63,500	>63,500	>63,500

Reprinted per IESNA 21-11. See luminaire datasheet for details.

**Guaranteed Performance:** The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

**Field Measurements:** Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

**Electrical System Requirements:** Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

**Installation Requirements:** Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



**We Make It Happen.**

Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2018 Musco Sports Lighting, LLC.

**ILLUMINATION SUMMARY**



# Madison Memorial High School

Madison, WI

## GRID SUMMARY

Name: Soccer  
 Size: 330' x 200'  
 Spacing: 30.0' x 30.0'  
 Height: 3.0' above grade

## ILLUMINATION SUMMARY

MAINTAINED HORIZONTAL FOOTCANDLES

Entire Grid  
 Guaranteed Average: 50  
 Scan Average: 50.99  
 Maximum: 63  
 Minimum: 41  
 Avg / Min: 1.25  
 Guaranteed Max / Min: 2  
 Max / Min: 1.56  
 UG (adjacent pts): 1.33  
 CU: 0.64  
 No. of Points: 84

LUMINAIRE INFORMATION

Color / CRI: 5700K - 75 CRI  
 Luminaire Output: 121,000 / 52,000 / 38,600 lumens  
 No. of Luminaires: 56  
 Total Load: 58.3 kW

Luminaire Type	Lumen Maintenance		
	L90 hrs	L80 hrs	L70 hrs
TLC-LED-1150	>63,500	>63,500	>63,500
TLC-BT-575	>63,500	>63,500	>63,500
TLC-LED-400	>63,500	>63,500	>63,500

Reported per TM-21-11. See luminaire datasheet for details.

**Guaranteed Performance:** The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

**Field Measurements:** Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

**Electrical System Requirements:** Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.


**Installation Requirements:** Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



**We Make It Happen.**

Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC ©1981, 2018 Musco Sports Lighting, LLC.

EQUIPMENT LIST FOR AREAS SHOWN								
QTY	LOCATION	Pole		Luminaires				
		SIZE	GRADE ELEVATION	MOUNTING HEIGHT	LUMINAIRE TYPE	QTY / POLE	THIS GRID	OTHER GRIDS
2	F1-F2	80'		15'	TLC-BT-575	2	2	0
				80'	TLC-LED-1150	11	11	0
2	F3-F4	80'		15'	TLC-BT-575	2	2	0
				50'	TLC-LED-400	1	1	0
				80'	TLC-LED-1150	12	12	0
4	TOTALS					56	56	0



Pole location(s) ⊕ dimensions are relative to 0,0 reference point(s) ⊗



# Madison Memorial High School

Madison, WI

## GRID SUMMARY

Name: Track  
 Size: Irregular  
 Spacing: 30.0' x 30.0'  
 Height: 3.0' above grade

## ILLUMINATION SUMMARY

### MAINTAINED HORIZONTAL FOOTCANDLES

Entire Grid  
 Scan Average: 16.34  
 Maximum: 44  
 Minimum: 0  
 Avg / Min: 76.92  
 Max / Min: 205.30  
 UG (adjacent pts): 0.00  
 CU: 0.12  
 No. of Points: 50

### ILLUMINAIRE INFORMATION

Color / CRI: 5700K - 75 CRI  
 Luminaire Output: 121,000 / 52,000 / 38,600 lumens  
 No. of Luminaires: 56  
 Total Load: 58.3 kW

Luminaire Type	Lumen Maintenance		
	L90 hrs	L80 hrs	L70 hrs
TLC-LED-1150	>63,500	>63,500	>63,500
TLC-BT-575	>63,500	>63,500	>63,500
TLC-LED-400	>63,500	>63,500	>63,500

Reported per TM-21-11. See luminaire datasheet for details.

**Guaranteed Performance:** The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

**Field Measurements:** Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

**Electrical System Requirements:** Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

**Installation Requirements:** Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.




**We Make It Happen.**

Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2018 Musco Sports Lighting, LLC.

## EQUIPMENT LIST FOR AREAS SHOWN

QTY	LOCATION	Pole		Luminaires				
		SIZE	GRADE ELEVATION	MOUNTING HEIGHT	LUMINAIRE TYPE	QTY / POLE	THIS GRID	OTHER GRIDS
2	F1-F2	80'		15'	TLC-BT-575	2	2	0
				80'	TLC-LED-1150	11	11	0
2	F3-F4	80'		15'	TLC-BT-575	2	2	0
				50'	TLC-LED-400	1	1	0
				80'	TLC-LED-1150	12	12	0
4	TOTALS					56	56	0




Pole location(s) ⊕ dimensions are relative to 0,0 reference point(s) ⊗



**EQUIPMENT LIST FOR AREAS SHOWN**

Pole		Luminaires						
QTY	LOCATION	SIZE	GRADE ELEVATION	MOUNTING HEIGHT	LUMINAIRE TYPE	QTY / POLE	THIS GRID	OTHER GRIDS
2	F1-F2	80'	-	15'	TLC-BT-575	2	2	0
				80'	TLC-LED-1150	11	11	0
2	F3-F4	80'	-	15'	TLC-BT-575	2	2	0
				50'	TLC-LED-400	1	1	0
				80'	TLC-LED-1150	12	12	0
4	TOTALS					56	56	0



Pole location(s) Ⓢ dimensions are relative to 0,0 reference point(s) ⊗

ENGINEERED DESIGN By: Connor Ramstead • File #163423-p-FB • 23-May-18

**Madison Memorial High School**  
Madison, WI

**GRID SUMMARY**

Name:	Bleachers
Size:	Irregular
Spacing:	10.0' x 10.0'
Height:	3.0' above grade

**ILLUMINATION SUMMARY**

MAINTAINED HORIZONTAL FOOTCANDLES			
Entire Grid			
Scan Average:	4.60		
Maximum:	14		
Minimum:	0		
Avg / Min:	21.04		
Max / Min:	62.20		
UG (adjacent pts):	3.10		
CU:	0.01		
No. of Points:	192		
LUMINAIRE INFORMATION			
Color / CRI:	5700K - 75 CRI		
Luminaire Output:	121,000 / 52,000 / 38,600 lumens		
No. of Luminaires:	56		
Total Load:	58.3 kW		
	Lumen Maintenance		
Luminaire Type	L90 hrs	L80 hrs	L70 hrs
TLC-LED-1150	>63,500	>63,500	>63,500
TLC-BT-575	>63,500	>63,500	>63,500
TLC-LED-400	>63,500	>63,500	>63,500

Reported per TM-21-11. See luminaire datasheet for details.

**Guaranteed Performance:** The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

**Field Measurements:** Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

**Electrical System Requirements:** Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

**Installation Requirements:** Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.




**We Make It Happen.**

Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2018 Musco Sports Lighting, LLC.

**ILLUMINATION SUMMARY**





## Madison Memorial High School

Madison, WI

### EQUIPMENT LAYOUT

**INCLUDES:**

- Football
- Soccer
- Track

**Electrical System Requirements:** Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

**Installation Requirements:** Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.

### EQUIPMENT LIST FOR AREAS SHOWN

QTY	LOCATION	Pole		Luminaire		QTY / POLE
		SIZE	GRADE ELEVATION	MOUNTING HEIGHT	LUMINAIRE TYPE	
2	F1-F2	80'	*	15'	TLC-BT-575	2
				80'	TLC-LED-1150	11
2	F3-F4	80'	*	15'	TLC-BT-575	2
				50'	TLC-LED-400	1
				80'	TLC-LED-1150	12
4	<b>TOTALS</b>					56

### SINGLE LUMINAIRE AMPERAGE DRAW CHART

Ballast Specifications (.90 min power factor)	Line Amperage Per Luminaire (max draw)					
	208 (60)	220 (60)	240 (60)	277 (60)	347 (50)	480 (60)
Single Phase Voltage	208 (60)	220 (60)	240 (60)	277 (60)	347 (50)	480 (60)
TLC-LED-1150	6.8	6.5	5.9	5.1	4.1	3.7
TLC-BT-575	3.2	3.0	2.8	2.4	1.9	1.7
TLC-LED-400	2.5	2.3	2.1	1.9	1.5	1.4



Pole location(s) ⊕ dimensions are relative to 0,0 reference point(s) ⊗

ENGINEERED DESIGN By: Connor Ramstead • File #163423-p-FB • 23-May-18



**We Make It Happen.**

Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC, ©1981, 2018 Musco Sports Lighting, LLC.

**EQUIPMENT LAYOUT**





Madison Memorial HS  
Field Aiming Diagram  
Madison, WI

CORPORATE OFFICE:  
P.O. Box 208  
100 1st Avenue West  
Oskaloosa, Iowa 52577  
800/825-8020

DATE:	BY:	DESCRIPTION:
05/23/18	CS	Revised Field Aiming Diagram
05/23/18	CS	Revised Field Aiming Diagram

DATE:	BY:	DESCRIPTION:
05/23/18	CS	Revised Field Aiming Diagram
05/23/18	CS	Revised Field Aiming Diagram

PALE QUANTITY	PALE LOCATION	MOUNTING HEIGHT	PALE ELEV.	LUMINAIRE TYPE	LUMINAIRE WATTAGE	ATTACHMENT LEGS	
1	A1	90'	0'	1500W AZ	0	0	
1	A2	80'	0'	1500W AZ	6	6	
1	B1	80'	0'	1500W AZ	10	10	
1	B2	80'	0'	1500W AZ	10	10	
1	C1	80'	0'	1500W AZ	4	4	
1	C2	80'	0'	1500W AZ	4	4	
1	D1	80'	0'	1500W AZ	3	3	
1	D2	80'	0'	1500W AZ	3	3	
<b>TOTALS</b>						<b>46</b>	<b>71.76</b>

Wind Design Criteria: IBC STD 2009 90MPH Exposure C

Lighting Equipment  
Project No: 153423-p-SB1  
Issue No: 2.1/2.5.1  
Date: 23/MAY/18

Field Name: Baseball  
Voltage: 480V  
3 PHASE  
Single Phase Voltage: 208/220/240/277/347/380/400/415/480  
1500 WATT METAL HALIDE LAMP: 8.6 18.3 7.7 7.5 16.5 15.1 4.7 4.4 4.2 3.7  
1000 WATT METAL HALIDE LAMP: 6.5 16.4 15.9 5.8 4.9 4.0 3.6 3.4 3.2 2.9

Overcurrent devices and conductors MUST be sized using the Manufacturer's rated ampere draw per luminaire (WA). Using the AW rating can result in undersized calculations. Refer to Musco's Control System Summary or Specification Chart (located below) for manufacturer's ampere draw.

Field Name	Pole I.D.	Laser Aiming Points
Baseball	A1	Pole 0 0
	A2	Pole 0 0
	B1	Pole 0 0
	B2	Pole 0 0
	C1	Pole 0 0
	C2	Pole 0 0
D1	Pole 0 0	
D2	Pole 0 0	

If you have questions pertaining to this document, please contact DONOR or Musco, your project engineer.  
CONTRACT NO: 805-8025 ext: 2153  
DATE: 05/23/18

This symbol represents the 0,0 point for locating poles.  
This field uses a 20' x 20' grid.  
This field has a 60' basepath.  
SOFTBALL FIELD: 324'/378'/336'  
FIELD ID: Baseball

The following poles ECE's will have spare fuses: A1  
Poles P1-P4 are donated from project #157610 to become poles A1, A2, B1, B2  
Fixtures 1-40 are donated from project #157610



Align weld marks located at bottom of pole sections @ 0(FIELD SIDE)



Information contained herein is the confidential property of James Spaul, Lighting. It is to be used only for the project and site identified herein. It is not to be used for any other project or site without the written consent of James Spaul, Lighting. © 2018 James Spaul, Lighting. All rights reserved.



**Pole / Fixture Summary**

Pole ID	Pole Height	Fixture Qty	Lamp Type	Circuit
A1	80'	6	1500W MZ	B
A2	80'	6	1500W MZ	B
B1	80'	10	1500W MZ	B
B2	80'	10	1500W MZ	B
C1	80'	4	1500W MZ	B
C2	80'	4	1500W MZ	B
D1	80'	3	1500W MZ	B
D2	80'	3	1500W MZ	B
<b>8</b>		<b>46</b>		

**Calculation Grid Summary**

Grid Name	Calculation Metric	Light Level			Uniformity		Circuits	Fixture Qty	
		Type	Ave	Min	Max	Max/Min			Ave/Min
Baseball (Infield)	Horizontal Illuminance	Constant	51	36	60	1.66	1.41	B	46
Baseball (Outfield)	Horizontal Illuminance	Constant	30.9	22	45	2.08	1.42	B	46


**Circuit Summary**

Circuit	Description	Load	Fixture Qty
B	Baseball	71.94 kW	46

**MY PROJECT**

Name: Madison Memorial High School  
 Location: Madison, WI

From Hometown to Professional



We Make It Happen®

**ENGINEERED DESIGN**

By: Connor Ramstead  
 File # / Date: 163423-p-5B3 18-Jun-18

Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2018 Musco Sports Lighting, LLC.

**PROJECT SUMMARY**



**EQUIPMENT LIST FOR AREAS SHOWN**

Pole			Luminaires					
QTY	LOCATION	SIZE	GRADE ELEVATION	MOUNTING HEIGHT	LAMP TYPE	QTY / POLE	THIS GRID	OTHER GRIDS
2	A1-A2	80'	-	80'	1500W MZ	6	6	0
2	B1-B2	80'	-	80'	1500W MZ	10	10	0
2	C1-C2	80'	-	80'	1500W MZ	4	4	0
2	D1-D2	80'	-	80'	1500W MZ	3	3	0
8	TOTALS					46	46	0



**MY PROJECT**

Name: Madison Memorial High School  
Location: Madison, WI

**GRID SUMMARY**

Name: Baseball  
Size: Irregular 324' / 379' / 326'  
Spacing: 30.0' x 30.0'  
Height: 3.0' above grade

**CONSTANT ILLUMINATION**

SUMMARY	HORIZONTAL FOOTCANDLES	
	Infield	Outfield
Guaranteed Average:	50	30
Scan Average:	50.96	30.85
Maximum:	60	45
Minimum:	36	22
Avg / Min:	1.41	1.42
Guaranteed Max / Min:	2	2.5
Max / Min:	1.66	2.08
UG (adjacent pts):	1.32	1.56
No. of Points:	25	100
LUMINAIRE INFORMATION		
Luminaire Type:	Green Generation	
Design Usage Hours:	5,000 hours	
Design Lumens:	134,000	
Avg Lamp Tilt Factor:	1.000	
No. of Luminaires:	46	
Avg KW:	71.94 (78.2 max)	

**Guaranteed Performance:** The Guaranteed Average CONSTANT ILLUMINATION described above is guaranteed for the design usage hours of the system.

**Field Measurements:** Illumination measured in accordance with IESNA RP-6-15 and CIBSE LG4. Individual values may vary. See the Warranty document for details.


**Electrical System Requirements:** Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

**Installation Requirements:** Results assume +/- 3% nominal voltage at line side of the ballast and structures located within 3 feet (1m) of design locations.

**ENGINEERED DESIGN**

By: Connor Ramstead  
File # / Date: 163423-p-SB3 18-Jun-18

Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2018 Musco Sports Lighting, LLC.




Pole location(s) Ⓧ dimensions are relative to 0,0 reference point(s) ⊗

**ILLUMINATION SUMMARY**






All drawings are the property of Musco Lighting, Inc. and are to be used only for the project and location specified. Any other use without the written consent of Musco Lighting, Inc. is strictly prohibited.



**POLE(S): P1-P4**  
 Musco 100FT Light-Structure System™ pole  
 Green Generation™ luminaires



**POLE(S): A1, A2**  
 Musco 80FT Light-Structure System™ pole  
 Green Generation™ luminaires

1. Cut off and grind smooth upper jacking brackets on section 2.
2. Apply cold galv. spray on exposed areas per instructions.
3. Cut 3'-6 3/4" off the top of the pole section 2.
4. Attach new filter from one the following methods:
  - A: Use lower jacking brackets.
  - B: Reweld the jacking brackets 55" from the new cut top of section 2.


ORDER NUMBER 165423P1	DATE 05/23/2018	BY NTS	R.L.
--------------------------	--------------------	-----------	------

DATE	BY	R.L.	REVISIONS


**MUSCO Lighting**  
 CORPORATE OFFICE:  
 P.O. Box 808  
 100 1st Avenue West  
 Oskaloosa, Iowa 52577  
 +1-800-525-6030  
 +1-841-873-0411

Madison Memorial High School  
 Madison, WI  
 Donated Pole Instructions

Musco Lighting, Inc. 3000 West 15th Street, P.O. Box 808, Okalosa, Iowa 52577  
 Phone: 800-825-6220 Fax: 562-893-0411  
 Website: www.musco.com



**POLE(S): P1-P4**  
 Musco 100FT Light-Structure System™ pole  
 Green Generation™ luminaires



**POLE(S): B1, B2**  
 Musco 80FT Light-Structure System™ pole  
 Green Generation™ luminaires

1. Cut off and grind smooth upper jacking brackets on section 2.
2. Apply cold galv. spray on exposed areas per instructions.
3. Cut 3'-6 3/4" off the top of the pole section 2.
4. Attach new fitter from one the following methods:
  - A: Use lower jacking brackets.
  - B: Reweld the jacking brackets 55" from the new cut top of section 2.

PROJECT NUMBER: 153423	DATE: 05/23/2016	BY: R.L.	REVISIONS:
CHECKED BY: N.T.S.			
DESIGNED BY: C.Reinhold			
PROJECT TITLE: 153423P1			

DATE:	BY:	R.L.	REVISIONS:

**MUSCO Lighting**  
 CORPORATE OFFICE:  
 P.O. Box 808  
 100 1st Avenue West  
 Okalosa, Iowa 52577  
 +1-800-825-6220  
 +1-562-893-0411

Madison Memorial High School  
 Madison, WI  
 Donated Pole Instructions



# PRELIMINARY FOUNDATION AND POLE ASSEMBLY DRAWING

TABLE 1: POLE ASSEMBLY

POLE ID	POLE HEIGHT (ft/in)	# OF LUMINAIRES	ASSEMBLED POLE WEIGHT (lb)
A1	80 (24.4)	6	3113 (1412)
A2	80 (24.4)	6	3113 (1412)
B1	80 (24.4)	10	3473 (1575)
B2	80 (24.4)	10	3473 (1575)
C1	80 (24.4)	4	2088 (952)
C2	80 (24.4)	4	2088 (952)
D1	80 (24.4)	3	1651 (749)
D2	80 (24.4)	3	1651 (749)
F1	80 (24.4)	13	4185 (1898)
F2	80 (24.4)	13	4185 (1898)
F3	80 (24.4)	15	4431 (2011)
F4	80 (24.4)	15	4431 (2011)

Pole Assembly Note:

- Steel pole should overlap concrete base and be sealed light with 1 1/2 ton come-along (contractor provided).
- Align weldmarks on steel sections before assembling.
- Assembled pole weight includes steel sections, crossarms, luminaires, and electrical components enclosures.
- Section overlap must be pulled together until tight. Overlap measurement should be +/- 6 in (150 mm).
- This document is not intended for use as an assembly instruction. See *Installation Instructions / Light Structure System™ Lighting System* for complete assembly procedure.


TABLE 2: FOUNDATION DETAILS

POLE ID	CONCRETE BASE WEIGHT (lb/kg)	BURIAL INFORMATION <sup>1,2</sup>		CUT BASE	LIGHTING PROTECTION <sup>3</sup> SUPPLEMENTAL INSTRUCTION
		F (ft/mm)	G (ft/mm)		
A1	5300 (2404)	30 (762)	16 (4.9)	NO	INTEGRATED <sup>4</sup>
A2	5300 (2404)	30 (762)	16 (4.9)	NO	INTEGRATED <sup>4</sup>
B1	5300 (2404)	30 (762)	16 (4.9)	NO	INTEGRATED <sup>4</sup>
B2	5300 (2404)	30 (762)	16 (4.9)	NO	INTEGRATED <sup>4</sup>
C1	3810 (1728)	30 (762)	14 (4.3)	NO	INTEGRATED <sup>4</sup>
C2	3810 (1728)	30 (762)	14 (4.3)	NO	INTEGRATED <sup>4</sup>
D1	2760 (1261)	30 (762)	12 (3.7)	NO	INTEGRATED <sup>4</sup>
D2	2760 (1261)	30 (762)	12 (3.7)	NO	INTEGRATED <sup>4</sup>
F1	5300 (2404)	30 (762)	16 (4.9)	NO	INTEGRATED <sup>4</sup>
F2	5300 (2404)	30 (762)	16 (4.9)	NO	INTEGRATED <sup>4</sup>
F3	5300 (2404)	30 (762)	16 (4.9)	NO	INTEGRATED <sup>4</sup>
F4	5300 (2404)	30 (762)	16 (4.9)	NO	INTEGRATED <sup>4</sup>

Foundation Notes

- Concrete backfill is calculated to 2 ft (0.6m) below grade (no average included). Top 2 ft (0.6m) to be class 5 soil compacted to 95% density of surrounding undisturbed soil unless otherwise specified in stamped structural design.
- Concrete backfill required 3000 (lb/ft<sup>3</sup>) (20 (MPa) minimum.
- Foundation design per 2009 IBC, 90 mph, exposure category C, vation STD.
- Assumes IBC class 5 soil.
- Standard bases include integrated lightning protection. If bases are cut, supplemental lightning protection is required. Contact Micro for materials and instruction.

Lighting protection is a manufacturer installed concrete encased electrode and connector. Ground connection is made when concrete base is installed and footing is poured. No additional steps required.



R60-60-00\_A

Musco Lighting Inc. 10000 Musco Blvd., Dayton, OH 45424-1000

Musco Lighting Inc. 10000 Musco Blvd., Dayton, OH 45424-1000  
 Date: 01/28/2019 Scale: N/A  
 Rev: 01/28/2019 Page: 1 of 1  
 Project: 181932 Designer: R. J. ...



# Control System Summary

## Project Specific Notes:

## Project Information

Project #: 163423  
 Project Name: Madison Memorial High School SO SB FB  
 Date: 05/24/18  
 Project Engineer: CRamstead  
 Sales Representative: Greg Smidt  
 Control System Type: Control and Monitoring  
 Communication Type: Digital Cellular  
 Scan: 163423-p-SB1,163423-p-FB  
 Document ID: 163423P3V1-0524093230  
 Distribution Panel Location or ID: Service FB  
 Total # of Distribution Panel Locations for Project: 2  
 Design Voltage/Hertz/Phase: 480/60/3  
 Control Voltage: 120

## Equipment Listing

DESCRIPTION	APPROXIMATE SIZE	
1. Control and Monitoring Cabinet	24 X 48	
	QTY	SIZE
Total Contactors	4	30 AMP
Total Off/On/Auto Switches:	1	

## Materials Checklist

### Contractor/Customer Supplied:

- A single control circuit must be supplied per distribution panel location.
  - If the control voltage is NOT available, a control transformer is required.
- Electrical distribution panel to provide overcurrent protection for circuits
  - Thermal/Magnetic circuit breaker sized per full load amps on Circuit Summary by Zone Chart
- Wiring:
  - Dedicated control power circuit
  - Power circuit to and from lighting contactors
  - Harnesses for cabinets at remote locations
  - Means of grounding, including lightning ground protection
- Electrical conduit wireway system
  - Entrance hubs rated NEMA 4: must be die-cast zinc, PVC, or copper-free die-cast aluminum
- Mounting hardware for cabinets
- Control circuit lock-on device to prevent unauthorized power interruption to control power
- Anti-corrosion compound to apply to ends of wire, if necessary

Call Control-Link Central™ operations center at 877/347-3319 to schedule activation of the control system upon completion of the installation.  
 Note: Activation may take up to 1 1/2 hours

## IMPORTANT NOTES

1. Please confirm that the design voltage listed above is accurate for this facility. Design voltage/phase is defined as the voltage/phase being connected and utilized at each lighting pole's ballast enclosure disconnect. Inaccurate design voltage/phase can result in additional costs and delays. Contact your Musco sales representative to confirm this item.
2. In a 3 phase design, all 3 phases are to be run to each pole. When a 3 phase design is used Musco's single phase luminaires come pre-wired to utilize all 3 phases across the entire facility.
3. One contactor is required for each pole. When a pole has multiple circuits, one contactor is required for each circuit. All contactors are UL 100% rated for the published continuous load. All contactors are 3 pole.
4. If the lighting system will be fed from more than one distribution location, additional equipment may be required. Contact your Musco sales representative.
5. A single control circuit must be supplied per control system.
6. Size overcurrent devices using the full load amps column of the Circuit Summary By Zone chart- Minimum power factor is 0.9.

*NOTE: Refer to Installation Instructions for more details on equipment information and the installation requirements*






# Control System Summary

Madison Memorial High School SO SB FB / 163423 - 163423-p-FB  
Service FB - Page 2 of 8

## Control-Link. Control and Monitoring System



Wire	Description	# of Wires	Typ. Wire Size (AWG)	Max. Wire Length (FT)	Wire from Musco	Notes
1	Line power to contactors, and equipment grounding conductor	Note A	Note B	27	No	A - E
2	Load power to lighting circuits	Note A	Note B	N/A	No	A - D
3	Control power (dedicated, 20A)	3	12	N/A	No	C, D

R60-32-00\_C

- Notes:
- A. Voltage and phasing per the notes on cover page.
  - B. Calculate per load and voltage drop.
  - C. All conduit diameters should be per code.
  - D. Refer to control and monitoring system installation instructions for more details on equipment information and the installation requirements.
  - E. Contact Musco if maximum wire length from circuit breaker to contactor exceeds value in chart.

**IMPORTANT:** Control (3) wires must be in separate conduit from line and load power wiring (1, 2).



# Control System Summary

Madison Memorial High School SO SB FB / 163423 - 163423-p-FB  
Service FB - Page 3 of 8

## SWITCHING SCHEDULE

Field/Zone Description	Zones
Football	1

CONTROL POWER CONSUMPTION	
120V Single Phase	
VA loading of Musco Supplied Equipment	INRUSH: 1568.0 SEALED: 194.8

CIRCUIT SUMMARY BY ZONE							
POLE	CIRCUIT DESCRIPTION	# OF FIXTURES	# OF DRIVERS	*FULL LOAD AMPS	CONTACTOR SIZE (AMPS)	CONTACTOR ID	ZONE
F1	Football	13	13	21.7	30	C1	1
F2	Football	13	13	21.7	30	C2	1
F3	Football	15	15	22.9	30	C3	1
F4	Football	15	15	22.9	30	C4	1

\*Full Load Amps based on amps per driver.





# Control System Summary

Madison Memorial High School SO SB FB / 163423 - 163423-p-FB  
Service FB - Page 4 of 8

PANEL SUMMARY						
CABINET #	CONTROL MODULE LOCATION	CONTACTOR ID	CIRCUIT DESCRIPTION	FULL LOAD AMPS	DISTRIBUTION PANEL ID (BY OTHERS)	CIRCUIT BREAKER POSITION (BY OTHERS)
1	1	C1	Pole F1	21.70		
1	1	C2	Pole F2	21.70		
1	1	C3	Pole F3	22.90		
1	1	C4	Pole F4	22.90		


ZONE SCHEDULE				
ZONE	SELECTOR SWITCH	ZONE DESCRIPTION	CIRCUIT DESCRIPTION	
			POLE ID	CONTACTOR ID
Zone 1	1	Football	F1	C1
			F2	C2
			F3	C3
			F4	C4



# Control System Summary

Madison Memorial High School SO SB FB / 163423 - 163423-p-SB1  
Service BB - Page 6 of 8

## Control-Link. Control and Monitoring System



Wire	Description	# of Wires	Typ. Wire Size (AWG)	Max. Wire Length (FT)	Wire from Musco	Notes
1	Line power to contactors, and equipment grounding conductor	Note A	Note B	27	No	A - E
2	Load power to lighting circuits	Note A	Note B	N/A	No	A - D
3	Control power (dedicated, 20A)	3	12	N/A	No	C, D

R60-32-00\_C

- Notes:
- A. Voltage and phasing per the notes on cover page.
  - B. Calculate per load and voltage drop.
  - C. All conduit diameters should be per code.
  - D. Refer to control and monitoring system installation instructions for more details on equipment information and the installation requirements.
  - E. Contact Musco if maximum wire length from circuit breaker to contactor exceeds value in chart.

**IMPORTANT:** Control (3) wires must be in separate conduit from line and load power wiring (1, 2).





# Control System Summary

Madison Memorial High School SO SB FB / 163423 - 163423-p-SB1  
Service BB - Page 7 of 8

## SWITCHING SCHEDULE

Field/Zone Description	Zones
Baseball	1

CONTROL POWER CONSUMPTION	
120V Single Phase	
VA loading of Musco Supplied Equipment	INRUSH: 2548.0
	SEALED: 298.8

BALLAST SPECIFICATIONS .90 Minimum Power Factor	VOLTAGE: 480v THREE PHASE						
BALLAST OPERATING VOLTAGE	208	220	240	277	347	380	480
1500 Watt Metal Halide Lamp Operating line amperage per fixture- maximum	8.6	8.3	7.5	6.5	5.1	4.7	3.7
1000 Watt Metal Halide Lamp Operating line amperage per fixture- maximum	6.5	6.4	5.8	4.9	4.0	3.6	2.9

CIRCUIT SUMMARY BY ZONE						
POLE	CIRCUIT DESCRIPTION	# OF FIXTURES	FULL LOAD AMPS	CONTACTOR SIZE (AMPS)	CONTACTOR ID	ZONE
A1	Baseball	6	14.8	30	C1	1
A2	Baseball	6	14.8	30	C2	1
B1	Baseball	10	25.9	30	C3	1
B2	Baseball	10	25.9	30	C4	1
C1	Baseball	4	11.1	30	C5	1
C2	Baseball	4	11.1	30	C6	1
D1	Baseball	3	7.4	30	C7	1
D2	Baseball	3	7.4	30	C8	1



# Control System Summary


Madison Memorial High School SO SB FB / 163423 - 163423-p-SB1  
 Service BB - Page 8 of 8

PANEL SUMMARY						
CABINET #	CONTROL MODULE LOCATION	CONTACTOR ID	CIRCUIT DESCRIPTION	FULL LOAD AMPS	DISTRIBUTION PANEL ID (BY OTHERS)	CIRCUIT BREAKER POSITION (BY OTHERS)
2	2	C1	Pole A1	14.80		
2	2	C2	Pole A2	14.80		
2	2	C3	Pole B1	25.90		
2	2	C4	Pole B2	25.90		
2	2	C5	Pole C1	11.10		
2	2	C6	Pole C2	11.10		
2	2	C7	Pole D1	7.40		
2	2	C8	Pole D2	7.40		

ZONE SCHEDULE				
ZONE	SELECTOR SWITCH	ZONE DESCRIPTION	CIRCUIT DESCRIPTION	
			POLE ID	CONTACTOR ID
Zone 1	1	Baseball	A1	C1
			A2	C2
			B1	C3
			B2	C4
			C1	C5
			C2	C6
			D1	C7
			D2	C8



201 S. Gammon Rd  
9-21-13



**SITE PLAN APPROVAL**  
(MGO 28-186)

Address 201 S. Gammon Rd  
 Permit # LM05PL-2018-00101  
 Date Submitted 7/25/18  
 Original \_\_\_\_\_ Revision # \_\_\_\_\_  
 Final Approval Date 8/17/18  
 Signature \_\_\_\_\_  
 Planning Department, City of Madison

SCALE: 1" = 100' - 1/8" = 100'

**MATERIALS KEY**

Architectural Firm: ARCHITECTURE INC.  
 201 S. Gammon Rd, Madison, WI 53717

NO.	DESCRIPTION	DATE	BY
1	ISSUED FOR PERMIT	8/17/18	[Signature]
2	REVISION		
3	REVISION		
4	REVISION		
5	REVISION		
6	REVISION		
7	REVISION		
8	REVISION		
9	REVISION		
10	REVISION		

**MEMORIAL H. S. Additions**  
 201 South Gammon Road  
 Madison, WI 53717

NO.	DESCRIPTION	DATE	BY
1	ISSUED FOR PERMIT	8/17/18	[Signature]
2	REVISION		
3	REVISION		
4	REVISION		
5	REVISION		
6	REVISION		
7	REVISION		
8	REVISION		
9	REVISION		
10	REVISION		

SITE PLAN  
**SI.1**

## LeRoy, Kevin M.

---

**From:** Kelso, Nancy <NKelso@cityofmadison.com>  
**Sent:** Thursday, August 1, 2019 9:09 AM  
**To:** LeRoy, Kevin M.  
**Cc:** McReynolds, Amber  
**Subject:** Filing of ZBA Notice of Decision - Edgewood High School  
**Attachments:** ZBA Notice of Decision.pdf

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

**\*\* EXTERNAL EMAIL MESSAGE \*\***

Good Morning,

The letter of notice from the Zoning Board of Appeals (copy attached) was issued and signed by board chair Winn Collins on Thursday July 18, 2019. It was presented to our office the morning of Friday July 19, 2019. Due to the power outage and subsequent shut down of city services the letter was not sent out until Monday July 22, 2019. Because of that situation, Monday July 22, 2019 is to be considered as the filing date of the notice of decision.

Thank you,

Nancy Kelso  
Administrative Clerk  
City of Madison Building Inspection Division  
Madison Municipal Building  
215 Martin Luther King Jr Blvd Suite 017  
Madison, Wisconsin 53703-2984  
Tel: 608-266-4556  
[NKelso@cityofmadison.com](mailto:NKelso@cityofmadison.com)



**Katherine R. Rist**

Foley & Lardner LLP  
150 E. Gilman Street  
Madison, WI 53703  
Tel: 608.258.4317  
Email: [krist@foley.com](mailto:krist@foley.com)

**From:** Elliott, Michael <[michael.elliott@edgewoodhs.org](mailto:michael.elliott@edgewoodhs.org)>  
**Sent:** Friday, November 2, 2018 10:29 AM  
**To:** Rist, Katherine R. <[KRist@foley.com](mailto:KRist@foley.com)>  
**Subject:** Fwd: Edgewood Highschool Athletic Field Use and the Adopted Master Plan

Katie

Here is the email from Matt.

Mike

----- Forwarded message -----

**From:** Tucker, Matthew <[MTucker@cityofmadison.com](mailto:MTucker@cityofmadison.com)>  
**Date:** Fri, Oct 26, 2018 at 11:32 AM  
**Subject:** Edgewood Highschool Athletic Field Use and the Adopted Master Plan  
**To:** Brian Munson <[bmunson@vandewalle.com](mailto:bmunson@vandewalle.com)>, Elliott, Michael <[michael.elliott@edgewoodhs.org](mailto:michael.elliott@edgewoodhs.org)>  
**Cc:** Parks, Timothy <[TParks@cityofmadison.com](mailto:TParks@cityofmadison.com)>, Stouder, Heather <[HStouder@cityofmadison.com](mailto:HStouder@cityofmadison.com)>, Arntsen, Allen <[district13@cityofmadison.com](mailto:district13@cityofmadison.com)>

Brian, Mike- The purpose of this message is to follow-up on our conversation earlier this week about the current usage of the athletic field, as that use relates to the adopted master plan for the Edgewood campus.

After the neighborhood meeting of Wednesday October 17, I became aware of the extensive use of the athletic field at the northwest corner of the site. I also closely reviewed the [adopted Master Plan](#), to determine how language in the master plan relates to the athletic field usage. Specifically, in the “Open Space Plan” (section 3.8) the approve master plan identifies the athletics field to be used for “team practices, physical education practices.” The lack of any further language in this section, or any other language in sections of the adopted Master Plan, leads me to the interpretation that current programming and usage of the field is operating outside of the allowances of the adopted Master Plan.

If you wish to continue the current level of programming on the field for 2019 and beyond, I believe that you will need to pursue an amendment to the approved Master Plan. I would be happy to talk with you, Alder Arntsen, and the neighborhood liaison committee, should you choose to explore a Master Plan amendment to expand the use of the athletic field. If you decide to continue with the current idea for a stadium expansion at the athletic field, you will also need to include language in this amendment that would incorporate allowing the current level of usage of the field to be allowable and continue.

The master plan does include some language contemplating future needs for the institution and its users. In the “Future Needs of Campus Institutions” (section 3.1) subsection on Athletics, reference is made to the lack of athletics and fitness space and to the difficulty of obtaining sites for off-campus and on-campus recreation. This section includes the language that “Multiple solutions, both on-and off-campus, will be necessary to meet these needs.” This language does not explore the broader neighborhood or community needs that Edgewood appears to be attempting to address with the usage of the athletic field, however, the absence of reference to the broader community would not prohibit the broader discussion on expanded use of the facility for other community users from taking place.

Let me know if you have any questions.

## **Matt Tucker**

Zoning Administrator

Building Inspection Division



**215 Martin Luther King jr Blvd. STE 017**

Madison, Wisconsin 53701-2984

Telephone: 608 266 4569

Email: [mtucker@cityofmadison.com](mailto:mtucker@cityofmadison.com)

[www.cityofmadison.com/bi](http://www.cityofmadison.com/bi)

--

Michael Elliott

President

Edgewood High School of the Sacred Heart

2219 Monroe St. Madison, WI 53711

(608) 257-1023 x 103

[edgewoodhs.org](http://edgewoodhs.org) | [facebook.com/EdgewoodHS](https://facebook.com/EdgewoodHS)



The preceding email message may be confidential or protected by the attorney-client or work-product privileges. It is not intended for transmission to, or receipt by, any unauthorized persons. If you have received this message in error, please (i) do not read it, (ii) reply to the sender that you received the message in error, and (iii) erase or destroy the message and any attachments or copies. Any disclosure, copying, distribution or reliance on the contents of this message or its attachments is strictly prohibited, and may be unlawful. Unintended transmission does not constitute waiver of the attorney-client privilege or any other privilege. Legal advice contained in the preceding message is solely for the benefit of the Foley & Lardner LLP client(s) represented by the Firm in the particular matter that is the subject of this message, and may not be relied upon by any other party. Unless expressly stated otherwise, nothing contained in this message should be construed as a digital or electronic signature, nor is it intended to reflect an intention to make an agreement by electronic means.

---

This e-mail and any attachments may contain privileged or confidential information. This e-mail is intended solely for the use of the individual or entity to which it is addressed. If you are not the intended recipient of this e-mail, you are hereby notified that any copying, distribution, dissemination or action taken in relation to the contents of this e-mail and any of its attachments is strictly prohibited and may be unlawful. If you have received this e-mail in error, please notify the sender immediately and permanently delete the original e-mail and destroy any copies or printouts of this e-mail as well as any attachments. To the extent representations are made herein concerning matters of a client of the firm, be advised that such representations are not those of the client and do not purport to bind them.



## Office of the City Attorney

Michael P. May, City Attorney

Patricia A. Lauten, Deputy City Attorney

### ASSISTANT CITY ATTORNEYS

Roger A. Allen  
Steven C. Brist  
Lara M. Mainella  
Amber R. McReynolds  
Marci A. Paulsen  
Adriana M. Peguero  
Kevin B. Ramakrishna

Kate M. Smith  
Jaime L. Staffaroni  
Johns W. Strange  
Doran E. Viste  
Brittany A. Wilson  
Jennifer A. Zilavy

Room 401, City-County Building  
210 Martin Luther King, Jr. Blvd.  
Madison, Wisconsin 53703-3345  
(Phone) 608-266-4511  
(Fax) 608-267-8715  
attorney@cityofmadison.com

LITIGATION ASSISTANT  
Patricia V. Gehler

August 20, 2019

BY EMAIL ONLY

Matthew D. Lee  
Foley & Lardner  
150 East Gilman St., Suite 500  
Madison, WI 53703

RE: Introduction From the Council Floor

Dear Mr. Lee:

I am responding to your letter of August 15, 2019, in which you claim some irregularity in the introduction of Legistar 56091, amendments to the CI District zoning. I disagree with your analysis.


One of the options set out in sec. 2.05(1)(b), MGO, is that a matter introduced from the floor may be "referred to the next Common Council meeting for action." This zoning amendment was referred to the next Council meeting for action. The ordinance does not speak to what happens in the interim. Although I have not conducted an exhaustive search, my recollection is that similar procedures have been followed in the past, when a matter introduced from the floor actually is considered by a committee before it comes back to the next Council meeting pursuant to sec. 2.05(1)(b), MGO.

Finally, as we know, courts will not intervene when the question is whether a legislative body follows its own procedures. *State ex rel. Ozanne v. Fitzgerald*, 2011 Wis. 43, ¶ 48-51.

August 20, 2019

Page 2

Sincerely,



Michael P. May  
City Attorney

CC: Mayor Rhodes-Conway  
All Alders  
ACA John Strange



[https://madison.com/wsj/news/local/govt-and-politics/madison-picks-judge-doyle-square-developer-offering-fewer-affordable-housing-units/article\\_b043cbf1-8724-5953-8b39-ba8782aeb7c3.html](https://madison.com/wsj/news/local/govt-and-politics/madison-picks-judge-doyle-square-developer-offering-fewer-affordable-housing-units/article_b043cbf1-8724-5953-8b39-ba8782aeb7c3.html)

BREAKING TOP STORY

## Madison picks Judge Doyle Square developer offering fewer affordable housing units

Emily Hamer | Wisconsin State Journal  
Sep 4, 2019

SALE! Subscribe for \$1/mo.



Construction crews work on the Judge Doyle Square project in Downtown Madison last month.

MICHELLE STOCKER, CAPITAL TIMES ARCHIVES

Emily Hamer | Wisconsin State Journal

fter months of negotiating with Gebhardt Development on the Judge Doyle Square project, the Madison City Council decided Tuesday to switch to a developer that will provide fewer affordable housing units, but a more feasible construction design.

On a near unanimous vote, the council picked Stone House Development — which the city’s negotiating team had initially recommended — to build an apartment complex above the soon-to-be-completed parking garage on the Madison Municipal Building block.

Gebhardt had proposed around 80 affordable housing units, while Stone House proposed around 40, with around half being just as affordable as Gebhardt and half being less affordable.

---

Ald. Mike Verveer, 4th District, said while he wanted as many affordable units as possible Downtown, it was time for the city to go with the “more practical” proposal after continued complications with Gebhardt.

Last week in a closed session, the Finance Committee recommended the city terminate negotiations with Gebhardt, which it had originally chosen to develop the block, after concerns over construction challenges.

Gebhardt had initially planned to construct the building using an engineered wood frame, but that building technique is not yet allowed under state law. Gebhardt proposed using steel and concrete instead, but that would require costly modifications to the base of the building to support the weight.

---

---

Richard Arnesen, vice president of Stone House Development, said his company's proposal would not require any modifications to the base of the building, which contains the parking garage and is known as the podium.

"We're at a time that we really need a straightforward development process," said Ald. Rebecca Kemble, 18th District.

Verveer said another factor that was considered when terminating negotiations with Gebhardt was that the developer planned to segregate the affordable housing units from the regular priced units.

Gebhardt had initially proposed setting aside 78 of 196 apartments for households with incomes at or below 60% of the county median income, or \$49,560 for a family of three.

---

---

In comparison, Stone House proposed a plan for 159 apartments, with 20 being for renters with household incomes at or below 60% of county medium income, and 17 for those with household incomes at or below 80% of county median income, or \$66,030



for a family of three.

---

## Support Local Journalism

Your membership makes our reporting possible.

SALE! Subscribe for \$1/mo.

---

The council also approved an amended proposal for the other block of Judge Doyle Square, where Beitler Real Estate of Chicago is developing a hotel.

Heather Stouder, city planning division director, said the changes are “minor” and include removing a floor of parking from the building. Around 40 parking stalls will be moved across the street.

## Further delay on Edgewood vote

---

The council also voted to further delay a decision on whether to repeal Edgewood High School’s master plan, which the city has said prohibits the school from hosting games on its athletic field.

Edgewood requested to repeal its master plan in July, but at an Aug. 26 meeting, the city Plan Commission voted to delay a vote on that request for three weeks. On that timeline, the master plan vote would have been taken up on the Sept. 16 Plan Commission meeting and the Oct. 1 city council meeting.

At Tuesday's meeting, the city council voted 15-4 to delay the master plan vote for more than a month to the Oct. 14 Plan Commission meeting and Oct. 15 City Council meeting.

---

Ald. Shiva Bidar, 5th District, said the reason for the delay was to allow another proposal to get through the Plan Commission and City Council first. That proposal would require Edgewood High School to apply with the city before making modifications, such as adding lights or a sound system, to its field if the master plan is repealed.

City Council members who serve on the Plan Commission said they would like to know what the council decides on the field modification measure before voting on the master plan repeal. The council voted to keep that proposal on the earlier, Sept. 16 and Oct. 1 timeline.

## Funds for Hmong elders approved

In other business, the council, allocated \$47,900 in 2019 and \$115,000 in 2020 to Freedom Inc. and the Hmong Institute to support programming for South East Asian seniors, including mental health treatment, housing, social activities and other services.

---

The funds were split evenly between the organizations because some Hmong elders had stronger ties to Freedom Inc., others to the Hmong Institute, and city council members wanted to support all elders.

*[Editor's note: This story has been updated to reflect a correction. An earlier version misstated the vote to select Stone House Development to develop part of the project. The voice vote was near unanimous.]*

---

## Get Government & Politics updates in your inbox!

Stay up-to-date on the latest in local and national government and political topics with our newsletter.

\* I understand and agree that registration on or use of this site constitutes agreement to its user agreement and [privacy policy](#).

---

Emily Hamer | Wisconsin State Journal



Emily Hamer is a general assignment reporter for the Wisconsin State Journal. She joined the paper in April 2019 and was formerly an investigative reporting intern at the Wisconsin Center for Investigative Journalism.

## Related to this story

### New proposals keep low-cost housing clustered together in Judge Doyle Square project

Aug 24, 2019



### Another setback for Judge Doyle Square, as city calls for new developer for portion of project

Aug 27, 2019



### Madison Mayor Satya Rhodes-Conway focusing on building relationships, staff

Aug 4, 2019



### Nice stretch of weather on tap for south-central Wisconsin

Sep 4, 2019



### Day one of capital budget talks includes election security plan, non-lethal police weapons

Sep 10, 2019



## Madison Plan Commission: Edgewood needs to apply with city to add lights, sound to field

Sep 17, 2019



## Is Madison's city government working for everyone? Officials encourage feedback

Sep 23, 2019



## Madison Finance Committee recommends \$4.1 million for affordable housing

Oct 8, 2019



## Madison City Council approves \$4.1 million for affordable housing on East, Far West sides

Oct 16, 2019



## Madison poised for deal with developer on Judge Doyle Square

Nov 15, 2019



---

## Madison committee recommends developer for grocery store, housing project on South Side

Nov 26, 2019





