



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017
215 Martin Luther King Jr. Blvd
Madison, Wisconsin 53703
Phone: (608) 266-4635
Fax (608) 267-8739
www.cityofmadison.com

****BY E-MAIL ONLY****

April 27, 2021

Andrew Wanek
Ginkgo House Architecture
3157 Milwaukee Street
Madison, Wisconsin 53714

RE: Legistar ID# 64583 | Accela ID: 'LNDUSE-2021-00020' -- Approval of a demolition permit to raze an existing single-family house and construct a new single-family residence in the Traditional Residential – Varied 1 (TR-V1) Zoning District at 2042 E Main Street.

Dear Andrew Wanek;

At its April 26, 2021 meeting, the Plan Commission found the standards met and **conditionally approved** your client's demolition permit for 2042 E Main Street. The conditions of approval in the following sections shall be satisfied prior to issuance of building permits for the project.

Please contact Brenda Stanley of the Engineering Division at (608) 261-9127 if you have any questions regarding the following six (6) items:

1. Obtain a Street Terrace permit for the proposed work (installation of the driveway apron, landscaping, etc.) This permit application is available and must be completed on line at <http://www.cityofmadison.com/engineering/permits.cfm> (MGO 10.08)
2. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development. The procedures and fee schedule is available online at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))
3. Revise plan to show the location of all rain gutter down spout discharge locations. (POLICY)
4. Revise plan set to show more information on proposed drainage for the site. Use either spot elevations and drainage arrows or proposed contours to show the required drainage information. It is necessary to show the location of drainage leaving the site to the public right-of-way. It may be necessary to provide information off the site to fully meet this requirement. (POLICY)

5. Submit, prior to plan sign-off but after all revisions have been completed, a digital CAD file (single file) to the Engineering Division that is to scale and represents final construction with any private storm and sanitary sewer utilities.
6. Submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West).

Please contact Jeff Quamme of the City Engineering Division–Mapping Section, at (608) 266-4097 if you have questions regarding the following three (3) items:

7. Identify on the plans the lot and block numbers of recorded Certified Survey Map or Plat.
8. Provide a full and complete legal description of the site or property being subjected to this application on the site plan.
9. The site plan appears to show the proposed dwelling to be located at the minimum side yards. Therefore, it is recommended that a boundary survey be performed by a Registered Professional Surveyor to confirm the property lines prior to construction.

Please contact Jenny Kirchgatter of the Zoning Division at (608) 266-4429 if you have any questions regarding the following two (2) items:

10. Section 28.185(7)(a)5. requires that if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Bryan Johnson at streets@cityofmadison.com. Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(7)(a)5. shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission.
11. On the site plan, show the extent of the roof eave projections into the setbacks. Roof eaves and gutters may encroach a maximum of three (3) feet into the front and rear yard setbacks and a maximum of two (2) feet into the side yard setbacks.

Please contact Bill Sullivan of the Madison Fire Department at (608) 261-9658 if you have any questions regarding the following two (2) items:

12. MFD recommends the installation of a fire sprinkler system to protect the occupants. Provide a quote option to install fire sprinkler protection in accordance with NFPA 13D.
13. Please consider allowing Madison Fire Dept. to conduct training sequences prior to demolition. Contact MFD Training Division to discuss possibilities: Division Chief Paul Ripp at pripp@cityofmadison.com or (608)712-6277.

Please contact Jeff Belshaw of the Water Utility at (608) 261-9835) if you have any questions regarding the following two (2) items:

14. The Madison Water Utility shall be notified to remove the water meter at least two working days prior to demolition. Contact the Water Utility Meter Department at (608) 266-4765 to schedule the meter removal appointment.
15. A Water Meter Application Form and fees must be submitted before connecting to the existing water lateral. Provide at least two working days notice between the application submittal and the scheduled lateral connection/extension. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

Please contact Brad Hofmann of the Forestry Division at (608) 267-4908 if you have questions regarding the following seven (7) items:

16. Contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at 266-4816. Penalties and remediation shall be required. Add as a note on the plan set.
17. As defined by the Section 107.13 of City of Madison Standard Specifications for Public Works Construction: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches in diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry (266-4816) prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing. Tree protection specifications can be found on the following website: <https://www.cityofmadison.com/business/pw/specs.cfm> Add as a note on the plan set.
18. On this project, street tree protection zone fencing is required. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and, extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on the plan set.
19. Street tree pruning shall be coordinated with Madison Forestry at a minimum of two weeks prior to the start of construction for this project. All pruning shall follow the American National Standards Institute (ANSI) A300 - Part 1 Standards for pruning. Add as a note on the plan set.
20. Soil Section 107.13(g) of City of Madison Standard Specifications for Public Works Construction addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on the plan set.

21. All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alderperson within who's district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the plan set.
22. An existing inventory of street trees located within the right of way shall be included on the landscape, site, demo, and utility plans. The inventory shall include the following: location, size (diameter at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is proposed to be removed and the reason for removal.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining permits for your project:

1. After the plans have been revised per the above conditions, please **one (1) complete digital plan set in PDF format** of complete, fully dimensioned, and to-scale plans; the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code; and any other documentation requested herein to the Zoning Administrator at zoning@cityofmadison.com. (Note that that an individual email cannot exceed 20MB and it is the responsibility of the applicant to present files in a manner that can be accepted. Please email zoning@cityofmadison.com regarding questions or if you need alternative filing options. The check for the site plan review fee shall be mailed to the City of Madison Building Inspection Division; PO Box 2984; Madison, WI 53701-2984.) The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant and property owner (if not the applicant) to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting building permit approval. [Signature block on last page]
3. City Agencies who submitted conditions of approval will review your revised plans to verify that their conditions, along with any applicable requirements, have been satisfied. When the revised plans are submitted, the applicant will be emailed a hyperlink to a website to follow, in real time, which agencies have reviewed the revised documents, and signed off or need additional information.
4. Approval of plans for this project does not include any approval to prune, remove or plant trees in the public right-of-way. Permission for such activities must be obtained from the City Forester, (608) 267-4908.
5. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.

If you have any questions regarding obtaining your demolition or building permits, please contact the Zoning Administrator at (608) 266-4551. If you have any other questions or if may be of any further assistance, please do not hesitate to contact my office at (608) 261-9135.

Sincerely,



Chris Wells
Planner

I hereby acknowledge that I understand and will comply with the above conditions of approval for this project.

<i>Signature of Applicant</i>

<i>Signature of Property Owner (if not the applicant)</i>

- cc: Brenda Stanley, Engineering Division
Jeff Quamme, City Engineering Division – Mapping
Jenny Kirchgatter, Zoning Administrator
Bill Sullivan, Fire Department
Jeff Belshaw, Water Utility
Brad Hofmann, Forestry
Bryan Johnson, Streets Division

LNDUSE-2021-00010			
For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Wells)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input checked="" type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Water Utility
<input type="checkbox"/>	Metro Transit	<input checked="" type="checkbox"/>	Other: Forestry