



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

126 S. Hamilton Street
P.O. Box 2985
Madison, Wisconsin 53701-2985
Phone: (608) 266-4635
Fax (608) 267-8739
www.cityofmadison.com

April 24, 2018

Jodi Shehadi
822 E Washington Ave #1415
Madison, WI 53703

RE: Approval of a demolition permit and conditional use to construct a single-family residence on a lakefront property at 4102 Veith Avenue (ID 50873; LNDUSE-2018-00026)

Dear Ms. Shehadi;

At its April 24, 2018 meeting, the Plan Commission found the standards met and **approved** your demolition permit and conditional uses for 4102 Veith Avenue. The conditions of approval in the following sections shall be satisfied prior to issuance of demolition or building permits for the project.

Please contact Brenda Stanley of the City Engineering Division at (608) 261-9127 if you have any questions regarding the following three (3) items:

1. Prior to approval, the owner or owner's representative shall obtain a permit to plug each existing sanitary sewer lateral that serves a building which is proposed for demolition. For each lateral to be plugged the owner shall complete a sewer lateral plugging application and pay the applicable permit fees. The permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14)).
2. All outstanding Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO16.23(9)(d)(4))
3. The Applicant shall obtain a Street Excavation Permit for the work in the Right of Way, which is available from the City Engineering Division.

Please contact Jenny Kirchgatter of Zoning at (608) 266-4429 if you have any questions regarding the following seven (7) items:

4. The lakefront yard setback is a minimum of 203.1'. The proposed lakefront yard setback is 126' 11". A variance is required from the Zoning Board of Appeals for a lakefront yard setback that is less than 203.1'.
5. The existing and new driveway as currently proposed do not meet the residential driveway design and location requirements Section 28.141(9). A single driveway with a maximum width of 22 feet at the property line may be constructed within the front yard setback. Alternatively, two driveways may be constructed within the front yard setback provided they meet the requirements of Section 28.141(9)(c).

6. Section 28.185(7)(a)5. requires that if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Bryan Johnson (608-266-4682).
7. Section 28.185(10) Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(7)(a)5. shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition.
8. Section 28.185(9)(a) A demolition or removal permit is valid for one (1) year from the date of the Plan Commission.
9. Filling, grading and excavation of the zoning lot may be permitted only where protection against erosion, sedimentation and impairment of fish and aquatic life has been assured. Obtain necessary erosion control permits.
10. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.

Please contact Bill Sullivan of the Fire Department at (608) 261-9658 if you have any questions regarding the following item:

11. Madison Fire Department recommends the installation of a residential fire sprinkler system in accordance with NFPA 13D. Additional information is available at the Home Fire Sprinkler Coalition website: <https://homefiresprinkler.org/building-residential-fire-sprinklers>.

Please contact Kathleen Kane of the Parks Division at (608) 261-9671 if you have any questions regarding the following item:

12. Existing street trees shall be protected. Please include the following note on the site plan: Contractor shall install tree protection fencing in the area between the curb and sidewalk and extend it at least 5 feet from both sides of the tree along the length of the terrace. No excavation is permitted within 5 feet of the outside edge of a tree trunk. If excavation within 5 feet of any tree is necessary, contractor shall contact City Forestry (266- 4816) prior to excavation to assess the impact to the tree and root system. Tree pruning shall be coordinated with City Forestry prior to the start of construction. Tree protection specifications can be found in section 107.13 of City of Madison Standard Specifications for Public Works Construction - <http://www.cityofmadison.com/business/pw/documents/StdSpecs/2018/Part1.pdf>. Any tree removals that are required for construction after the development plan is approved will require at least a 72 hour wait period before a tree removal permit can be issued by Forestry, to notify the Alder of the change in the tree plan.

Please contact Adam Wiederhoeft of the Water Utility at (608) 266-9121 if you have any questions regarding the following three (3) items:

13. All operating private wells shall be identified and permitted by the Water Utility in accordance with MGO 13.21. All unused private wells shall be abandoned in accordance with MGO 13.21.
14. The Madison Water Utility shall be notified to remove the water meter at least two working days prior to demolition. Contact the Water Utility Meter Department at (608) 266-4765 to schedule the meter removal appointment.

15. A Water Meter Application Form and fees must be submitted before connecting to the existing water lateral. Provide at least two working days notice between the application submittal and the scheduled lateral connection/extension. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumberscontractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

Please contact my office at (608) 243-0554, if you have questions regarding the following item:

16. The following information is provided for the reference of the applicant as many lakefront properties are associated with locations of Native effigy mounds and archaeological sites.

Burial Sites Preservation (§ 157.70):

(2r) Site Disturbance Prohibited. Except as provided under subs (4) and (5) and State Statute 157.111 and 157.112, no person may intentionally cause or permit the disturbance of a burial site or catalogued land contiguous to a cataloged burial site.

(3) Report of Disturbed Burial Sites. (a) Except as provided under s. 979.01, a person shall immediately notify the Wisconsin Historical Society (608-264-6502) if the person knows or has reasonable grounds to believe that a burial site or the cataloged land contiguous to a cataloged burial site is being disturbed or may be disturbed contrary to the requirements of subs. (4) and (5).

Many lakefront properties are associated with locations of Native American effigy mounds and archeological sites. This site is known to be associated with archeological and historic resources. The Burial Sites Preservation statute requires that the property owner contact the Wisconsin Historical Society to discuss the location of the proposed project and any possible disturbance of an archaeological or historic resource before the work commences. During the construction work, if a burial site disturbance occurs, the work shall stop immediately until the Wisconsin Historical Society is able to assess the site.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.


Please now follow the procedures listed below for obtaining permits for your project:

1. After the plans have been revised per the above conditions, please file **ten (10) sets** of complete, fully dimensioned, and to-scale plans, the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, 126 S. Hamilton Street. **This submittal shall all also include one (1) complete digital plan set in PDF format.** The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.

2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
3. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.
4. A conditional use approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.
5. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.
6. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at 243-0554.

Sincerely,



Sydney Prusak
 Planner

cc:

- Brenda Stanley, Engineering
- Jenny Kirchgatter, Zoning
- Bill Sullivan, Fire Department
- Bryan Johnson, Streets Division
- Kathleen Kane, Parks Division
- Adam Wiederhoeft, Water Utility
- Sean Malloy, Traffic Engineering

I hereby acknowledge that I understand and will comply with the above conditions of approval for the conditional use permit.

Signature of Applicant

Signature of Property Owner (if not the applicant)

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Prusak)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input checked="" type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Metro Transit
<input checked="" type="checkbox"/>	Water Utility		