

Madison Water Utility
Status of Unit Wells Offline for Repairs or Upgrades
11/15/2025

Region	Unit Well	Lost Supply (GPM)	Date Offline	Expected Online	Status of Repair/Replacement
A/B	13	2,200	09/2025	12/2025	Replacement equipment has been ordered
C	19	2,200	10/2024	12/2025	Chemical feed equipment supply delay

GPM = gallons per minute; 1,000 gpm = 1.44 MGD (million gallons per day)