



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Agenda - Approved

BUILDING CODE, FIRE CODE AND LICENSING APPEALS BOARD

Wednesday, May 28, 2008

12:15 PM

215 Martin Luther King, Jr. Blvd.
Room LL-130 (Madison Municipal Building)

If you need an interpreter, translator, materials in alternate formats or other accommodations to access this service, activity or program, please call the phone number below at least three business days prior to the meeting.

Si necesita un intérprete, un traductor, materiales en formatos alternativos u otros arreglos para acceder a este servicio, actividad o programa, comuníquese al número de teléfono que figura a continuación tres días hábiles como mínimo antes de la reunión.

Yog hais tias koj xav tau ib tug neeg txhais lus, ib tug neeg txhais ntawv, cov ntawv ua lwm hom ntawv los sis lwm cov kev pab kom siv tau cov kev pab, cov kev ua ub no (activity) los sis qhov kev pab cuam, thov hu rau tus xov tooj hauv qab yam tsawg peb hnuv ua hauj lwm ua ntej yuav tuaj sib tham.

Если Вам необходима помощь устного или письменного переводчика, а также если Вам требуются материалы в иных форматах либо у Вас имеются особые пожелания в связи с доступом к данной услуге, мероприятию или программе, пожалуйста, позвоните по указанному ниже телефону и сообщите об этом не менее чем за три рабочих дня до соответствующей встречи.

Neighborhood Preservation & Inspection Division at 608-266-4551 or TTY/TextNet 866-704-2318.

CALL TO ORDER / ROLL CALL

PUBLIC COMMENT

Three minutes allotted per individual.

1. [10457](#) 575 Science Drive

Lauri Kempfer, Flad Architects, appealing IBC 1003.3.1.8, Locks and Latches. The rule requires that egress doors be openable without a key or "special knowledge or effort". The variance requested is to provide special security to meet Federal Guidelines to have a bio-secure facility. The variance requested is to have facility personnel trained to use a special procedure. The Madison Fire Department supports the variance with annual training.

Attachments: [575 Science Drive.pdf](#)

ADJOURNMENT