



# City of Madison

City of Madison  
Madison, WI 53703  
www.cityofmadison.com

## Meeting Minutes - Approved BUILDING CODE, FIRE CODE AND LICENSING APPEALS BOARD

---

Wednesday, May 28, 2008

12:15 PM

215 Martin Luther King, Jr. Blvd.  
Room LL-130 (Madison Municipal Building)

---

### CALL TO ORDER / ROLL CALL

The meeting was called to order by Colin Godding.

Staff Present: Harry Sulzer and William Sullivan.

Present: 5 -

Colin L. Godding; Richard J. Link; Paul E. Karow; Randall V. Baldwin and James I. Glueck

Excused: 3 -

James I. Statz; Lyle G. Christian and Russell G. Stern

### PUBLIC COMMENT

None

1. [10457](#) 575 Science Drive

Lauri Kempfer, Flad Architects, appealing IBC 1003.3.1.8, Locks and Latches. The rule requires that egress doors be openable without a key or "special knowledge or effort". The variance requested is to provide special security to meet Federal Guidelines to have a bio-secure facility. The variance requested is to have facility personnel trained to use a special procedure. The Madison Fire Department supports the variance with annual training.

Attachments: [575 Science Drive.pdf](#)

Lauri Kempfer appealing IBC Section 1003.3.1.8. There was discussion that the Variance had been submitted to both the State and City. Randy Baldwin was to verify after the meeting that the State had approved the Variance.

A motion was made by Glueck, seconded by Karow, to table the Variance. The motion passed by voice vote other. The Variance was withdrawn by applicant after it was determined that it had been submitted to the State. A refund of \$490 will be issued to applicant.

### ADJOURNMENT

