

BPW Meeting February 8, 2012:

Review of Projects by Engineering Environmental Staff for Impacts to Water Resources

7. **W Gorham, N Henry, N Frances Street Assessment District**

This project will disturb over 4000 square feet but less than one acre, and so will require only a City Engineering Erosion Control and Stormwater Management Permit. (Corey Stelljes, City Engineering)

Prepared By: Genesis Steinworst

Date: 2/3/12