

Firchow, Kevin

From: Fred Lubcke [REDACTED]
Sent: Thursday, June 05, 2014 8:02 PM
To: Firchow, Kevin
Subject: RE: Staff Report

Hi Kevin, Sorry for not getting back to you sooner. The retaining wall in question is on average 3 feet tall part of the wall is replacing the existing wall which was falling down. The total length of the new wall will be 60 feet in length. The wall is a Unilock concrete modular wall block with drain tile and clear stone for backfill. This wall takes 90% of the runoff to the back of the lot and not into neighbor's yard which lower in elevation. Hope this clears this up, any question shoot me an e-mail.

Thanks,

Fred @ Cornerstone Designs