



NOTE: Available fire flow based on the demand at hour 85 of a Maximum 10-Day scenario and is equivalent to Maximum Day demand.

	Pipe Diameter 8 inch or less 10 - 14 inch 16 inch and greater	Fire Flow Criteria 0 gpm 1,000 gpm 2,000 gpm 2,500 gpm 3,500 gpm	Junction Fire flow Category Available Flow Meets Criteria Available Flow 75% - 99% Criteria Available Flow 50% - 74% Criteria Available Flow < 50% Criteria	Other Symbols Floating Storage Booster Pump Station Well Pressure Zone Boundary Streets
--	---	--	--	---