

City of Madison Fire Department Position Statement


Owner: Cheryl Parzych & Dana Lytle	Project Name: 2 nd & 3 rd floor alterations	Contact:
Address: 1102 Sherman Ave Madison, WI 53703	Building Location: 1102 Sherman Ave Madison, WI 53703	Address:
Owner Phone: 608-770-5623 Email: cheryl@artworksherpa.com	Building Occupancy or Use: Single-family home	Phone: Email:

Rule Being Petitioned: SPS 321.03(3)

I have read the application for variance and recommend: (check appropriate box)

Approval
 Conditional Approval
 Denial
 No Comment

- Any future alterations of the first floor shall include extension of the fire sprinkler system.
- Previous petition for variance approval and current codes require hard wired interconnected smoke alarms on all floor levels. MFD would support new technology smoke alarms that have a 10-year lithium battery and wireless interconnection.

Name of Fire Chief or Designee (type or print) Bill Sullivan, Fire Protection Engineer	
City of Madison Fire Department 	Telephone Number 608-261-9658
Signature of Fire Chief or Designee	Date Signed April 16, 2021