

Department of Planning & Development **Planning Unit**

Website: www.cityofmadison.com

Madison Municipal Building 215 Martin Luther King, Jr. Boulevard P.O. Box 2985 Madison, Wisconsin 53701-2985 TDD 608 266-4747 FAX 608 266-8739 PH 608 266-4635

January 5, 2007

Lance T. McGrath Union Corners, LLC 103 N. Hamilton Street Madison, Wisconsin 53703

RE: File No. LD 0655 – Certified survey map – 54-58 Farwell Street.

Dear Mr. McGrath:

The two-lot certified survey of property located at 54-58 Farwell Street, Section 6, Township 7N, Range 10E, City of Madison, Dane County, Wisconsin, is hereby **conditionally approved**. The site is zoned R4 (General Residence District). The conditions of approval from the reviewing agencies for the CSM are:

Please contact Janet Dailey, City Engineering, at 261-9688 if you have questions regarding the following seven conditions:

- 1. The bike path along the southern edge of Lot 2 shall be constructed prior to building permits being issued for Lot 2 or prior to the final grading of the property after the house is built. The developer shall work with the City Engineer to coordinate the construction of the bike path.
- 2. Lot corner elevations shall be shown on both existing and proposed lot corners.
- 3. The northwest lot corner elevation is not legible.
- 4. Each lot shall have a separate sanitary lateral.
- 5. Prior to approval show sewer service plans including elevations of proposed basement, laterals, and existing main.
- 6. The developer shall enter into a City/developer agreement for the installation of public improvements required to serve this CSM. The developer shall be required to provide deposits to cover City labor and materials and surety to cover the cost of construction. The developer shall meet with the City Engineer to schedule preparation of the plans and the agreement. The City Engineer will not sign off on this CSM without the agreement executed by the developer.
- 7. The applicant shall construct sidewalk along Farwell Street to a plan approved by the City Engineer.
- 8. Arrows shall be added to the certified survey map indicating the direction of drainage for each property line not fronting on a public street. In addition, the certified survey map shall include lot corner elevations, for all lot corners, to the nearest 0.25-foot. The following notes shall be added to the certified survey map.
 - a.) Arrows indicate the direction of surface drainage swale at individual property lines. Said drainage swale shall be graded with the construction of each principal structure and

LD 0655 54-58 Farwell Street January 5, 2007 Page 2

maintained by the lot owner unless modified with the approval of the City Engineer. Elevations given are for property corners at ground level and shall be maintained by the lot owner.

b.) All lots within this survey are subject to a public easement for drainage purposes which shall be a minimum of 6-feet in width measured from the property line to the interior of each lot except that the easement shall be 12-feet in width on the perimeter of the certified survey map. Easements shall not be required on property lines shared with green ways or public streets. No structures may be constructed within said easement and no other obstructions to drainage, including landscaping are permitted without the prior written approval of the City Engineer.

Note: In the event of the City of Madison Plan Commission and/or Common Council approve re-division of a previously subdivided property, the underlying public easements for drainage purposes are released and replaced by those required and created by the current approved subdivision.

9. Prior to the issuance of building permits, the developer shall submit a master stormwater drainage plan to the City Engineering Division for review and approval which shows lot corner elevations to the nearest 0.25-foot. For purposes of the plan, it shall be assumed that grading shall be done on a straight-line grade between points unless other information is provided. The proposed slope between points shall always be greater than or equal to .0075 ft/ft. If a break in grade is required between lot corners a shot shall be taken at that break in grade to provide the Engineer with enough information to interpret the plan. The developer shall also show proposed drainage arrows on the plan to indicate the proposed direction of drainage.

The master storm water drainage plan shall be submitted to City Engineering in digital format with elevations/grades/contours shown on the recorded plat map of the development. The digital record shall be provided using the state plane coordinate system – NAD 27.

The following note shall accompany the master storm water drainage plan:

"For purposes of this plan, it is assumed that grading shall be a straight line grade between points unless otherwise indicated. All slopes shall be 0.75% or steeper. Grade breaks between lot corners are shown by elevation or through the use of drainage arrows."

No building permits shall be issued prior to City Engineering's approval of this plan.

- 10. A minimum of two (2) working days prior to requesting City Engineering signoff on the CSM the applicant shall contact Janet Dailey (261-9688) to obtain the final stormwater utility charges that are due and payable prior to sub-division of the properties. The stormwater utility charges (as all utility charges) are due for the previous months of service. All charges shall be cleared prior to the land division (and subsequent obsolesces of the existing parcel).
- 11. Wisconsin Administrative Code A-E 7.08 identifies when Public Land System (PLS) tie sheets must be filed with the Dane County Surveyor's office. The developer's surveyor and/or applicant must submit copies of required tie sheets or condition reports for all monuments, including center of sections of record, used in this survey, to Eric Pederson, City Engineering. If a new tie sheet is not required under A-E 7.08, Engineering requests a copy of the latest tie sheet on record with Dane County Surveyor's office. The applicant shall identify monument types on all PLS corners included on the Plat or CSM. Note: Land tie to two PLS corners required.

LD 0655 54-58 Farwell Street January 5, 2007 Page 3

12. Prior to Engineering final sign-off by main office for Certified Survey Maps (CSM), final CSM must be submitted to Engineering Division Surveyor/ Land Records Coordinator for final technical review and approval. This submittal must occur a minimum of two working days prior to final Engineering Division sign-off. Electronic mail submittal of the **final CSM in PDF form** is preferred. Please transmit to epederson@cityofmadison.com

Please contact Dennis Cawley, Madison Water Utility, at 266-4651 if you have any questions regarding the following item:

13. This lot division will require the extension of public water main and the installation of new public water service laterals.

Please note that the City Real Estate Office has reviewed the report of title provided with this survey and has provided comments to you separately. If you have any questions about those comments, please contact Jeff Ekola at 267-8719 for more information.

A resolution authorizing the City to sign the CSM and any other documents related to the proposed land division was approved by the Common Council on January 2, 2007.

As soon as the comments and conditions have been satisfied as verified with a completed affidavit form (enclosed), the original along with the revised Certified Survey Map, with all signatures and approvals from the reviewing agencies, shall be brought to this office for final signoff. You or your client may then record the certified survey at the Dane County Register of Deeds. For information on recording procedures and fees, contact the Register of Deeds at 266-4141.

Upon acceptance and recording of the certified survey map by the Dane County Register of Deeds, please transfer the recorded volume, document number, and page numbers to the copies and forward a copy to this office for our records. The original survey map with the recording information is permanently kept on file in the Dane County Register of Deeds Office. A copy of the recorded document can be obtained from the Register of Deeds Office, Room 110, City-County Building or the Real Estate Office in the Madison Department of Planning and Development.

Any appeal from this action, including the conditions of approval, must be filed with the Circuit Court within thirty (30) days from the date of this letter. The approval of this CSM shall be null and void if not recorded in **six months** from the date of the approving resolution. If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at 261-9632.

Sincerely,

Timothy M. Parks Planner

cc: Janet Dailey, Engineering Division
Kathy Voeck, Assistant Zoning Administrator
Jeff Ekola, Real Estate Development Unit
Norb Scribner, Dane County Land Records and Regulations