



# City of Madison

City of Madison  
Madison, WI 53703  
www.cityofmadison.com

## Agenda - Approved

### BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD

---

Tuesday, March 25, 2014

12:15 PM

215 Martin Luther King, Jr. Blvd.  
Room LL-110 (Madison Municipal Building)

---

If you need an interpreter, translator, materials in alternate formats or other accommodations to access this service, activity or program, please call the phone number below immediately.

Si necesita un intérprete, un traductor, materiales en formatos alternativos u otros arreglos para acceder a este servicio, actividad o programa, comuníquese inmediatamente al número de teléfono que figura a continuación.

Yog tias koj xav tau ib tug neeg txhais lus, ib tug neeg txhais ntawv, cov ntaub ntawv ua lwm yam los sis lwm cov kev pab kom siv tau qhov kev pab, kev ua num los sis kev pab cuam no, thov hu rau tus xov tooj hauv qab no tam sim no.

Building Inspection Division, 608-266-4551

#### CALL TO ORDER / ROLL CALL

#### PUBLIC COMMENT

Three minutes allotted per individual.

#### DISCLOSURES AND RECUSALS

Members of the body should make any required disclosures or recusals under the City's Ethics Code.

#### PETITION FOR VARIANCE

[33481](#)

540 State Street (C-03-14-2014)  
IEBC 912.2 requires sprinklers for this change of use in the second floor. The existing water service is 1 1/2" - 2" and is inadequate to sprinkle the second level. It will cost \$55,000 to put in a 4" main. The proposal is to sprinkle the dining areas and both stairwells. The Fire Department requires the system be monitored and a new 4" main be provided within 8 years.

**Attachments:** [540 State Street.pdf](#)

#### ADJOURNMENT