



Department of Planning & Community & Economic Development
Planning Division

Website: www.cityofmadison.com

Madison Municipal Building
215 Martin Luther King, Jr. Boulevard
P.O. Box 2985
Madison, Wisconsin 53701-2985
TDD 608 266-4747
FAX 608 266-8739
PH 608 266-4635

December 12, 2012

Brian Stoddard
Avenue Architects, Inc
550 Sunrise Drive #201
Spring Green, WI 53588

RE: Approval to rezone **638 Hercules Trail** from PUD-GDP (Planned Unit Development Plan-General Development Plan) to PUD-GDP-SIP (Planned Unit Development-General Development Plan-Specific Implementation Plan) to allow for the construction of two (2) apartment buildings with 95 total units

Dear Mr. Stoddard:

At its December 11, 2012 meeting, the Common Council approved your client's application for a Zoning Map Amendment for 638 Hercules Trail from PUD-GDP (Planned Unit Development Plan-General Development Plan) to PUD-GDP-SIP (Planned Unit Development-General Development Plan-Specific Implementation Plan) to allow for the construction of two (2) apartment buildings with 95 total units. The following conditions of approval shall be satisfied prior to final approval and recording of the Specific Implementation Plan.

Please contact Janet Dailey, City Engineering Division, at 261-9688 if you have questions regarding the following twenty-one (21) items:

1. The applicant shall coordinate the terrace tree planting plan with the fire access plan.
2. There are preliminary lighting assessments against these properties (Lots 453 and 454 of Grandview Commons) that were established at the time of the plat approval process. The City may install and assess lighting in conjunction with this development.
3. The pending Certified Survey Map for this property shall be completed and recorded with the Register of Deeds (ROD). When the recorded CSM image is available from the ROD, the Assessors Office can then create the new Address-Parcel-Owner (APO) data in GEO so that the Accela system can upload this data and permit issuance made available for this new land record.
4. In accordance with 10.34 MGO – STREET NUMBERS - Submit a PDF of each floor plan to Engineering Mapping Lori Zenchenko (Lzenchenko@cityofmadison.com) so that a preliminary interior addressing plan can be developed. If there are any changes pertaining to the location of a unit, the deletion or addition of a unit, or to the location of the entrance into any unit, (before, during or after construction) the addresses may need to be changed. The interior address plan is subject to the review and approval of the Fire Marshal.
5. The approved base address for proposed Bldg A is 5816 Halley Way and Bldg B 5804 Halley Way.

6. The applicant shall provide the City Engineer with a survey indicating the grade of the existing sidewalk and street. The Applicant shall hire a Professional Engineer to set the grade of the building entrances adjacent to the public right of way. The Applicant shall provide the City Engineer the proposed grade of the building entrances. The City Engineer shall approve the grade of the entrances prior to signing off on this development (POLICY).
7. The applicant shall replace all sidewalk and curb and gutter which abuts the property which is damaged by the construction or any sidewalk and curb and gutter which the City Engineer determines needs to be replaced because it is not at a desirable grade regardless of whether the condition existed prior to beginning construction (POLICY).
8. All work in the public right-of-way shall be performed by a City licensed contractor (MGO 16.23(9)(c)5 and MGO 23.01).
9. All street tree locations and tree species within the right of way shall be reviewed and approved by City Forestry. Please submit a tree planting plan (in PDF format) to Dean Kahl, of the City Parks Department - dkahl@cityofmadison.com or 266-4816. Approval and permitting of any tree removal or replacement shall be obtained from the City Forester and/or the Board of Public Works prior to the approval of the site plan (POLICY).
10. All damage to the pavement on Hercules Trail, Halley Way, Jupiter Drive, Charon Lane, adjacent to this development shall be restored in accordance with the City of Madison's Pavement Patching Criteria. For additional information please see the following link:
<http://www.cityofmadison.com/engineering/patchingCriteria.cfm>
11. The plan set shall be revised to show a proposed private internal drainage system on the site. This information shall include the depths and locations of structures and the type of pipe to be used (POLICY and MGO 10.29).
12. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
13. Effective January 1, 2010, The Department of Commerce's authority to permit commercial sites, with over one (1) acre of disturbance, for stormwater management and erosion control has been transferred to the Department of Natural Resources (WDNR). The WDNR does not have an authorized local program transferring this authority to the City of Madison. The City of Madison has been required by the WDNR to continue to review projects for compliance with NR216 and NR-151 but a separate permit submittal is now required to the WDNR for this work as well. The City of Madison cannot issue our permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process.
14. As this site is greater than one (1) acre, the applicant is required by State Statute to obtain a Water Resources Application for Project Permits (WRAPP) from the Wisconsin Department of Natural Resources, prior to beginning construction. This permit was previously known as a Notice of Intent Permit (NOI). Contact Eric Rortvedt at 273-5612 of the WDNR to discuss this requirement. Information on this permit application is available on line at: <http://dnr.wi.gov/Runoff/stormwater/constrformsinfo.htm> (NOTIFICATION).
15. Prior to approval, this project shall comply with MGO Chapter 37 regarding stormwater management. Specifically, this development is required to:
 - a) Control 80% TSS (5 micron particle) off of new paved surfaces.
 - b) Provide infiltration in accordance with MGO Chapter 37.
 - c) Provide oil & grease control from the first 1/2" of runoff from parking areas.

- d) Complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website – as required by MGO Chapter 37.

16. The applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Program Specialist in the Engineering Division (Lori Zenchenko). The digital CAD file shall be to scale and represent final construction. The single CAD file submittal can be either AutoCAD (dwg) Version 2001 or older, MicroStation (dgn) Version J or older, or Universal (dxf) format and contain only the following data, each on a separate layer name/level number:

- a) Building Footprints
- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Misc Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
- e) Right-of- way lines (public and private)
- f) All Underlying Lot lines or parcel lines if unplatted
- g) Lot numbers or the words “unplatted”
- h) Lot/Plat dimensions
- i) Street names

All other levels (contours, elevations, etc) are not to be included with this file submittal.

NOTE: Email file transmissions preferred zenchenko@cityofmadison.com. Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement during construction will require a new CAD file (POLICY and MGO 37.09(2) & 37.05(4)).

17. The applicant shall submit, prior to plan sign-off, digital PDF files to the Engineering Division (Jeff Benedict or Tim Troester). The digital copies shall be to scale, and shall have a scale bar on the plan set (POLICY and MGO 37.09(2)). PDF submittals shall contain the following information:

- a) Building footprints.
- b) Internal walkway areas.
- c) Internal site parking areas.
- d) Lot lines and right-of-way lines.
- e) Street names.
- f) Stormwater Management Facilities.
- g) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans).

18. The applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including:

- a) SLAMM DAT files.
- b) RECARGA files.
- c) TR-55/HYDROCAD/Etc.
- d) Sediment loading calculations

If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided (POLICY and MGO 37.09(2)).

19. The applicant shall obtain a Street Excavation permit for the installation of utilities required to serve this project. The Applicant shall pay the permit fee, inspection fee and street degradation fee as applicable and shall comply with all the conditions of the permit (MGO 10.05(6)). This permit application is available on line at: <http://www.cityofmadison.com/engineering/permits.cfm>.

20. The applicant's utility contractor shall obtain a connection permit and excavation permit prior to commencing the storm sewer construction MGO 37.05(7). This permit application is available on line at: <http://www.cityofmadison.com/engineering/permits.cfm>.
21. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service (POLICY).

Please contact Pat Anderson, Assistant Zoning Administrator, at 266-5978 if you have any questions regarding compliance with the following six (6) items.

22. Bike parking shall comply with MGO Section 28.11. Provide 95 bike parking stalls (one per unit) in a safe and convenient location on an impervious surface to be shown on the final plan. NOTE: A bike parking stall is two feet by six feet with a five-foot access area. Structures that require a user-supplied locking device shall be designed to accommodate U-shaped locking devices. Moped parking must also be shown, if provided.
23. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with MGO Chapter 31, Sign Codes. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.
24. Put addresses of the building and number of units in each building on the final plan sets, pursuant to MGO Section 10.34(2). Address information can be obtained from Lori Zenchenko of City Engineering at 266-5952.
25. Parking lot plans with greater than twenty (20) stalls shall comply with MGO Section 28.04(12). Landscape plans must be stamped by a registered landscape architect. Provide a landscape worksheet with the final plans that shows that the landscaping provided meets the point and required tree ordinances. In order to count toward required points, the landscaping shall be within 15' and 20' of the parking lot depending on the type of landscape element. (Note: The required trees do not count toward the landscape point total). Planting islands shall consist of at least 75% vegetative cover, including trees, shrubs, ground cover, and/or grass. Up to 25% of the island surface may be brick pavers, mulch, or other non-vegetative cover. All plant materials in islands shall be protected from vehicles by concrete curbs.
26. Include elevations of buildings as part of final plan submittal
27. Provide three (10' x 35') loading areas with 14' vertical clearance to be shown on the plan. The loading area shall be exclusive of drive aisle and maneuvering space.

Please contact Bill Sullivan, Madison Fire Department, at 261-9658 to if you have questions regarding the following item:

28. The Madison Fire Department does not object to this proposal provided the project complies with all applicable fire codes and ordinances.

Please contact Kay Rutledge, Madison Parks Division, at 266-4714 if you have questions regarding the following three (3) items:

29. This development is within the Door Creek impact fee district (SI23). The developer shall pay approximately \$214,692.40 for park dedication and development fees for the new 95 multifamily units proposed. (See calculation of 2012 rates below. Rates will be higher if paid after 2012).

Fees in lieu of dedication = (95 mf @ \$1,631) = \$154,945.00
Park development fees = (95 mf @ \$628.92) = \$59,747.40
Total Fees = \$214,692.40

30. The developer must select a method for payment of park fees before signoff on the PUD(SIP).
31. Approval of plans for this project does not include any approval to prune, remove, or plant trees in the public right-of-way. Permission for such activities must be obtained from the City Forester, 266-4816.

Please contact Dennis Cawley, Madison Water Utility, at 261-9632 to if you have questions regarding the following item:

57. All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility. This property is not in a Wellhead Protection District. The Water Utility will not need to sign off the final plans, and not need a copy of the approved plans.

Please contact my office at 267-1150 if you have questions regarding the following item.

32. As required by the Zoning Code for Planned Unit Developments, the applicant shall provide proof of financing which provides assurances that the project will be completed once started, in a form acceptable to the Director of the Department of Planning and Community and Economic Development prior to the sign-off and recording of the PUD and any permits being issued. This information should include a letter of commitment from a bank or other lending institution and a letter from a construction company indicating their intent to proceed with the project or other commitments as required by the Director.

The applicant is also required to satisfy the conditions of approval of the Urban Design Commission prior to the final staff approval of the project and the issuance of building permits. Please contact Al Martin, Urban Design Commission Secretary, at 267-8740 if you have any questions about those conditions.

Please now follow the procedures listed below:

Please revise your plans per the above conditions and submit twelve (12) copies of a complete, fully dimensioned and scaled plan set to the Zoning Administrator, Room LL-100, Madison Municipal Building, 215 Martin Luther King, Jr. Boulevard for final review and comment. Please also provide the appropriate site plan review fee pursuant to section 28.12 (13)(a)10. Fees Received at Zoning Counter. Also be sure to include any additional materials requested by these departments for their approval prior to sign off. The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their signature of final approval.

Upon receipt of the aforementioned plans, documents and fees, and upon determining that they are complete, the Zoning Administrator shall record them with the Dane County Register of Deeds Office. The recorded originals will be returned to the applicant, with the recording information noted, when the Register of Deeds has completed the recording process.

If this plan is not recorded within one year of the date of approval by the Common Council, the approval shall be null and void. No construction or alteration of the property included in this application shall be permitted until a Specific Implementation Plan (SIP) has been approved and recorded.

Within thirty-six (36) months of Common Council approval of the general development plan, the basic right of use for the areas, when in conformity with the approved specific implementation plan, shall lapse and be null and void unless 1) the project, as approved, is commenced by the issuance of a building permit, or 2) if an application for an extension is filed at least thirty (30) days prior to the expiration of the thirty-six (36) month period and the Plan Commission, after a public hearing pursuant to Sec. 28.12(10)(e), determines that no changes in the surrounding area or neighborhood since approval of the general development plan render the project incompatible with current conditions and grants an extension of up to twenty-four (24) months in which to obtain a building permit. In no case shall an extension allow a building permit to be issued more than sixty (60) months after approval of the general development plan by the Common Council. If a new building permit is required pursuant to sec. 29.06(4), Madison General Ordinances, a new petition and approval process shall be required to obtain general development plan approval and specific implementation plan approval.

If you have any questions regarding recording this plan or obtaining permits, please call Matt Tucker, Zoning Administrator, at 266-4551. If I may be of any further assistance, please do not hesitate to contact me at 267-1150.

Sincerely,

Kevin Firchow, AICP
Planner

cc: Janet Dailey, City Engineering Division
Eric Halvorson, Traffic Engineering Division
Bill Sullivan, Madison Fire Department
Pat Anderson, Zoning
Kay Rutledge, Parks Division

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Firchow)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input checked="" type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Other: