

**Madison Water Utility**  
**Status of Unit Wells Offline for Repairs or Upgrades**  
**8/15/2025**

Region	Unit Well	Lost Supply (GPM)	Date Offline	Expected Online	Status of Repair/Replacement
A/B	15	1,400	03/2019	09/2025	Final equipment testing & calibration on-going; startup planned for early September
C	19	2,200	10/2024	10/2025	Treatment system installation is on-going; could be operational by late September

GPM = gallons per minute; 1,000 gpm = 1.44 MGD (million gallons per day)