

BPW Meeting May 5, 2010:

Review of Projects by Engineering Environmental Staff for Impacts to Water Resources

17. Allied Drive Redevelopment

This project will disturb over an acre, which will require a WRAPP from the DNR and an Erosion Control/Stormwater Management Permit from City Engineering. (Chris Petykowski, City Engineering)

38. Cannonball Path Phase 1

This project shall disturb over one acre of land, which will require a WRAPP from the DNR and an erosion Control/Stormwater Management Permit from City Engineering. (Anthony Fernandez, City Engineering)

Prepared By:

Murray Bill

Date:

5/5/10