

February 3, 2005

Howard Licht
Held & Associates, Inc.
6601 Grand Teton Plaza
Madison, Wisconsin 53719

RE: File No. LD 0437 – Certified survey map – 3751 Mammoth Trail

Dear Mr. Licht:

The two-lot certified survey of property located at 3751 Mammoth Trail, Section 11, Township 6N, Range 8E, City of Madison, Dane County, Wisconsin, is hereby **conditionally approved**. The site is zoned PUD-SIP (Planned Unit Development, Specific Implementation Plan) and has been approved for use as a daycare facility and townhomes.

The conditions of approval from the reviewing agencies for the CSM are:

Please contact Gary Dallmann, City Engineering, at (608) 266-4751 if you have questions regarding the following seven items:

1. Lots created by this CSM shall meet MGO Chapter 37 with regard to thermal control at the time they develop.
2. If the lots within this certified survey map are inter-dependent upon one another for storm water runoff conveyance, and/or a private drainage system exists for the entire site an agreement shall be provided for the rights and responsibilities of all lot owners. Said agreement shall be reviewed and placed on file by the City Engineer, referenced on the CSM and recorded at the Dane County Register of Deeds.
3. Arrows shall be added to the certified survey map indicating the direction of drainage for each property line not fronting on a public street. In addition, the certified survey map shall include lot corner elevations, for all lot corners, to the nearest 0.25-foot. The following notes shall be added to the certified survey map.
 - a. Arrows indicate the direction of surface drainage swale at individual property lines. Said drainage swale shall be graded with the construction of each principal structure and maintained by the lot owner unless modified with the approval of the City Engineer. Elevations given are for property corners at ground level and shall be maintained by the lot owner.
 - b. All lots within this certified survey are subject to public easements for drainage purposes which shall be a minimum of 6-feet in width measured from the property line to the interior of each lot except that the easements shall be 12-feet in width on the perimeter of the certified

survey. For purposes of two (2) or more lots combined for a single development site, or where two (2) or more lots have a shared driveway agreement, the public easement for drainage purposes shall be a minimum of six (6) feet in width and shall be measured only from the exterior property lines of the combined lots that create a single development site, or have a shared driveway agreement, except that the easement shall be twelve (12) feet in width along the perimeter of the certified survey. Easements shall not be required on property lines shared with greenways or public streets. No buildings, driveways, or retaining walls shall be placed in any easement for drainage purposes. Fences may be placed in the easement only if they do not impede the anticipated flow of water.

4. In accordance with Section s. 236.18(8), Wisconsin Statutes, the Applicant shall reference **City of Madison NAD 1927 Coordinates** on all PLS corners on the Plat or Certified Survey Map in areas where this control exists. The Surveyor shall identify any deviation from City Master Control with recorded and measured designations. City of Madison has established NAD 1927 Coordinates on all PLS corners within its corporate boundary. Visit the City of Madison Engineering Division web site for current tie sheets and control data. If a surveyor encounters an area without a published NAD 1927 value, contact Engineering Division for this information.
5. In accordance with Section s.236.34(1) (c) which says a CSM shall be prepared in accordance with s.236.20(2) (c) & (f), Wisconsin Statutes, the Applicant must show type, location and width of any and all easements. Clearly identify the difference between existing easements (site Register of Deeds recording data) and easements that are being conveyed by the Plat/CSM. Identify the owner and/or benefiting interest of all easements.
6. Wisconsin Administrative Code A-E 7.08 identifies when Public Land System (PLS) tie sheets must be filed with the Dane County Surveyor's office. The Developer's Surveyor and/or Applicant must submit copies of required tie sheets or condition reports for all monuments, including center of sections of record, used in this survey, to Eric Pederson, City Engineering. If a new tie sheet is not required under A-E 7.08, Engineering requests a copy of the latest tie sheet on record with Dane County Surveyor's office. The Applicant shall identify monument types on all PLS corners included on the Plat or CSM. Note: Land tie to two PLS corners required.
7. The Applicant shall submit to Eric Pederson, prior to Engineering sign-off of the subject plat, two (2) digital and one (1) hard copy of the final plat to the Mapping/GIS Section of the Engineering Division. The digital copies shall be submitted in both NAD27 & WIDOT County Coordinate System, Dane County Zone datums and be consistent with previous formats delivered to the City by the Applicant and contain the minimum of the following, each on a separate layer name/level number: right of way lines (public and private); lot lines; lot numbers; lot/plat dimensions; street names, and; easement lines (i.e. street, sanitary, storm (including wetland & floodplain boundaries) water, pedestrian/bike/walkway, or any public and/or private interest easement except local service for Cable TV, gas, electric and fiber optics).

*This transmittal is a separate requirement than the required submittals to Bob Arseneau for design purposes.

*New electronic final plat transmittals and notification of changes which occur to the final plat during the time the Engineering Division signs off and receives the digital copies of said plat and the recording thereof, are the responsibility of the Developer/Surveyor.

Please contact Kathy Voeck, the Acting Zoning Administrator, at 266-4551 if you have questions regarding the following item:

8. Show the approved lot boundaries of this CSM on the final PUD-SIP plans for signoff of the proposed daycare. All Zoning Administrator conditions of approval for the PUD-SIP shall be met.

Please note that the City Real Estate Office is reviewing the report of title provided with this survey and may have comments. That office will send any comments to you by fax. If you have any questions, please contact Jeff Ekola at 267-8719 for more information.

A resolution authorizing the City to sign the Certified Survey Map and any supporting documentation will be heard by the Common Council on February 22, 2005.

Note that signoff and approval to record the CSM does not constitute final approval for the PUD-SIP. No building permits may be issued based on this approval letter.

As soon as the comments and conditions have been satisfied as verified with a completed affidavit form (enclosed), the original along with the revised Certified Survey Map, with all signatures and approvals from the reviewing agencies, shall be brought to this office for final signoff. You or your client may then record the certified survey at the Dane County Register of Deeds. For information on recording procedures and fees, contact Register of Deeds at 266-4141.

Upon acceptance and recording of the certified survey map by the Dane County Register of Deeds, please transfer the recorded volume, document number, and page numbers to the copies and forward a copy to this office for our records.

The original survey map with the recording information is permanently kept on file in the Dane County Register of Deeds Office. A copy of the recorded document can be obtained from the Register of Deeds Office, Room 110, City-County Building or the Real Estate Office in the Madison Department of Planning and Development.

Any appeal from this action, including the conditions of approval, must be filed with the Circuit Court within thirty (30) days from the date of this letter. The approval of this CSM shall be null and void if not recorded in two years from the date of the approving resolution. If you have any questions or if you may be of any further assistance, please do not hesitate to contact my office at (608) 261-9632.

Sincerely,

Timothy M. Parks
Planner

cc: Gary Dallmann, Engineering Division
Kathy Voeck, Acting Zoning Administrator
Jeff Ekola, Real Estate Development Unit
Norb Scribner, Dane County Land Records and Regulations