

From: Sullivan, William
Sent: Monday, May 18, 2015 12:42 PM
To: Zellers, Ledell; Parks, Timothy
Subject: 1200 E Wash Plan commission Comment

Hello Ledell, Tim,

Feel free to provide feedback on my proposed verbiage:

Aerial fire lanes shall be free from overhead obstructions. Obstructions shall not be located between the building and an aerial fire lane. Alternative measures to allow obstructions may include specific tree selection and placement; increased fire protection systems; and/or increased building fire resistance. Alternatives must be approved by MFD prior to site plan approval.

Tim, this would replace MFD comments for 1200 E Washington. Our intent is not the removal of trees but rather a performance approach to fire operations and safety.

Thanks, Bill

Bill Sullivan
Fire Protection Engineer
City of Madison Fire Department
30 W. Mifflin Street, 9th Floor
Madison, WI 53703
608.261.9658 (Phone)
wsullivan@cityofmadison.com
www.madisonfire.org

